



DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive
Joseph T. Parisi

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director
Gerald J. Mandli

RFB# 312012 ADDENDUM NO. 2

ISSUE DATE: June 19, 2012

CAMROCK PEDESTRIAN/BICYCLE BOARDWALK CAMBRIDGE, WISCONSIN 53523

BID DATE AND TIME IS UNCHANGED

This Addendum forms part of the Construction Documents and modifies the original Construction Documents dated June 7, 2012. Acknowledge receipt of this Addendum by inserting the number and issue date in the blank space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of two (1) pages total. Note drawings are to be printed in 30x42" sheets

ADDITIONAL INFORMATION:

Included with this Addendum is a copy of the soil boring information from a previous nearby project. There is no guarantee that the soil for this project will be identical, this information is only for reference.

CHANGES TO PROCUREMENT AND CONTRACTING REQUIREMENTS

Instructions to Bidders, page ITB – 3, Section 8 Commencement and Completion of Work, Sub B
The completion date reads “September 31, 2012”. It is now changed to “October 31, 2012”

Conditions of Contract, page CC – 5, Section 5, Sub B

In the second sentence the phrase “The Contractor” in reference to which party shall obtain permits, shall be changed to “The County”.

CHANGES TO DRAWINGS:

Wetland Boardwalk Construction Details, Sheet E

The cross section from the 10,000 pound case is to be used in the Bid

The decking is to be treated lumber, not composite material

The Railing requirements for the Wisconsin DNR are as follows:

Where railings are judged necessary, they must be a minimum of 42 inches in height above the deck and designed to prevent the passage of an object with a diameter greater than 6 inches (as per current Department of Commerce code).

