



# DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive  
Kathleen M. Falk

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713  
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director  
Gerald J. Mandli

March 27, 2009

## ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

### RFB NO. 109062 - ADDENDUM NO. 1

#### NEW CENTRAL AIR CONDITIONING SYSTEM

---

**BIDS DUE:** THURSDAY, APRIL 2, 2009, 2:00 PM. DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.

---

This Addendum is issued to modify, explain or clarify the original RFB and is hereby made a part of the RFB. **Acknowledge receipt of all addenda on Bid Form.**

#### PLEASE MAKE THE FOLLOWING CHANGES:

**1. Air Cooled Condensing Unit**

The air cooled condensing unit must be an R-22 Energy Star rated unit. Therefore, on the Air Cooled Condensing Unit Schedule, which is located on the Drawing, change the unit information to the following:

Model Number: 2TTX5048A1000A

SEER: 15

MCA: 26

All other schedule data remains the same.

**2. Electrical Drawing Notes**

On the partial electrical plan, add the following note:

“Relocate the existing 2-lamp, 4-foot fluorescent lighting fixture on the ceiling as required to coordinate with the location of the new ductwork being installed.”

**3. Bid Bond**

Bid bond or certified check for 5% of bid is no longer required with this bid. 100% performance / payment bond is still required on this project for the successful bidder.

If any additional information about this Addendum is needed, please contact John Welch at 608/267-8815 or [welch@co.dane.wi.us](mailto:welch@co.dane.wi.us).

Enclosures:  
N/A