



DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive
Joseph T. Parisi

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director
Gerald J. Mandli

July 20, 2017

ATTENTION ALL REQUEST FOR PROPOSAL (RFP) HOLDERS
RFP NO. 317025 - ADDENDUM NO. 2
PROFESSIONAL ENGINEERING SERVICES FOR BIOGAS FACILITY
DANE COUNTY LANDFILL SITE #2
7102 U.S. HIGHWAY 12 & 18
MADISON, WISCONSIN

PROPOSALS DUE: TUESDAY, AUGUST 1, 2017, 2:00 PM.
DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM

This Addendum is issued to modify, explain or clarify the original Request for Proposal (RFP) and is hereby made a part of the RFP. **Proposers must acknowledge this addendum on the Addendum form and submit with Proposal as outlined in RFP Cover Letter.**

PLEASE MAKE THE FOLLOWING CHANGES:

1. Requested Services and Business Information

a. Section 1 – General Information:

The office/spare parts building is predicted to be approximately 1,000 square feet with a minimum height of 12 feet.

A/E must coordinate with Vendor when designing for pipeline interconnection and necessary utilities.

For Base Proposal – Part 2, please allot time and resources for interconnection review with pipeline company.

Pipeline operating pressures range from a minimum of 400 psig to a maximum of 852 psig. Per interconnect agreement the biogas cleaning system will operate at a minimum of 600 psig and maximum of 852 psig.

Receipt of the following addenda and inclusion of their provisions in this Proposal is hereby acknowledged:

Addendum No(s). _____ through _____

Dated _____

Signature _____

If any additional information about this Addendum is needed, please contact John Welch at (608) 516-4154, or Welch@countyofdane.com.