



CITY OF MADISON FIRE DEPARTMENT

325 West Johnson St., Madison, WI 53703-2295
(Phone) 608-266-4420 ♦ (FAX) 608-267-1100 ♦ Internet: fire@cityofmadison.com

Fire Protection System Work Permit

December 3, 2009

Dawn Weber
Dorschner Associates, Inc.
849 E. Washington Ave., Ste. 112
Madison, WI 53703

RE: 210 Martin Luther King Jr. Boulevard – CCB Exit Stair Doors 4-1, 1003b, 2-3, 3-3, 1-4, 4-4, 1-5, & 4-5

The City of Madison Fire Department (MFD) has reviewed the construction documents for the installation of locking hardware on stair doors for the referenced project. The construction documents demonstrate substantial compliance with the applicable codes and are hereby conditionally approved. The following are the conditions of approval:

1. The MFD review and conditional approval of the construction documents shall not be deemed or construed as approval to violate any provisions of the applicable codes.
2. The hardware and system design and installation must comply with the applicable codes and standards. (E.g. 34.24, *Madison General Ordinance*; Comm 61 to 65, *Wisconsin Commercial Building Code*; Comm 16, *Electrical Code*; and NFPA 72, *National Fire Alarm Code*, 2007 Edition.)
3. All device locations shall be inspected and approved by MFD prior to the installation of sheetrock or other materials that conceal system components.
4. All electrical wiring, conduit, and power supply connections shall be inspected and approved by the City of Madison Building Inspection Unit 608-266-4551.
5. The installing contractor shall conduct a complete system pretest prior to scheduling the system acceptance test with this office. A re-inspection fee of \$50.00 will be assessed if the system or system components fail to meet the codes.
6. Final approval is subject to the completion of satisfactory inspection and acceptance tests witnessed by an inspector of the MFD. Contact Fire Inspector Scott Strassburg at 608-261-9843 **at least 48 hours in advance** to schedule a date and time to meet your technicians at the job site.
7. **A copy of the approved plans, specifications and this conditional approval letter must be available at the job site during construction.**

If you have any questions regarding the above, please contact me at 608-261-9658. Your continued cooperation is greatly appreciated.

Sincerely,

Bill Sullivan
Fire Protection Engineer

CC: Scott Strassburg [City of Madison Fire Department] 213009
Rob Nebel [Dane. Co. Public Works, 1919 Alliant Energy Center Way, Madison, WI 53713]

Debra H. Amesqua
Fire Chief
608-266-6564

James D. Keiken
Assistant Chief
608-266-5966

Michael C. Dirienzo
Assistant Chief
608-266-5959

Paul T. Bloom
Assistant Chief
608-266-5956

Gregg D. Knudtson
Division Chief
608-266-4203

Ernesto Martinez
Division Chief
608-266-4886

Ronald C. Schwenn
Division Chief
608-267-8674

Jeffrey G. Duppler
Division Chief
608-266-4201

Michael D. Popovich
Division Chief
608-266-5946

Arthur B. Price
Division Chief
608-266-4256

Edwin J. Ruckriegel
Fire Marshal
608-266-4457

Rita A. Johnson
Admin. Services Mgr.
608-266-5957

Fire Investigation
608-266-4488

Visit our web site at:
www.madisonfire.org