



**DANE COUNTY DEPT. OF
PUBLIC WORKS, HIGHWAY &
TRANSPORTATION**

1919 Alliant Energy Center Way
Madison, Wisconsin 53713
Office: 608/266-4018 ♦ Fax: 608/267-1533
Public Works Engineering Division

ADDENDUM

MAY 11, 2021

ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

RFB NO. 321001 - ADDENDUM NO. 01

DANE COUNTY JCO / NIP SECURITY UPGRADES

BIDS DUE: TUESDAY, MAY 25, 2021, 2:00 PM.
DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

PLEASE NOTE RESPONSES TO THE FOLLOWING BIDDER-SUBMITTED QUESTIONS

Q1: Are there the same slab moisture issues with the floor at the NIP area as are present at the JCO area?

A1: No, testing did not indicate the same slab moisture issues at the NIP.

Q2: Can you clarify the intended flooring finishes at the NIP area, and what is in the base bid vs. Addendum 1?

A2: The base bid includes new carpeting and vinyl base at NIP Corridor 107, NIP Work Area 107A, NIP Mail 107D, NIP Reception 107F, and NIP Corridor 122 and associated demolition. Addendum #1 includes new VCT and vinyl base at NIP Corridor 112, NIP Corridor 122A and NIP Corridor 122B and associated demolition. Please refer to Room Finish Schedule on Drawing Sheet A800.

PLEASE MAKE THE FOLLOWING CHANGES:

CONSTRUCTION DRAWINGS:

1. Sheet G001

Modify sheet index to include Drawing Sheet A101.

2. Sheet AD101

Clarify location and extents of temporary partition at JCO.

Clarify location of base bid flooring demolition and Alternate #1 flooring demolition at NIP.

3. Sheet A101

Modify size of JCO Alcove J065B.

4. Sheet A401

Modify size of JCO Alcove J065B.

Add transaction window at glass at JCO Alcove J065B.

Add power and data at JCO Alcove J065B – refer to electrical drawings.

5. Sheet A800

Clarify notes at finish schedule.

Revise Decorative Laminated Glazing basis of design pattern.

6. Sheet E201

Modify current Sheet E201 as shown on Drawing 1 as follows: Add receptical, conduit, and wiring to JCO Alcove J065B.

7. Sheet T100

Modify current Sheet T100 as shown on Drawing 1 as follows: Modify location of existing data room.

8. Sheet T101

Modify current Sheet T101 as shown on Drawing 1 as follows: Add data connection, duress button and associated conduits to JCO Alcove J065B.

If any additional information about this Addendum is needed, please contact Eric Urtes, AIA – Public Works Project Manager at 608/266-4798, urtes.eric@countyofdane.com.

Sincerely,

Eric Urtes, AIA

Dane County Public Works Project Manager

Enclosures:

Drawing Sheet	G001
Drawing Sheet	AD101
Drawing Sheet	A101
Drawing Sheet	A401
Drawing Sheet	A800
Drawing Sheet	E201
Drawing Sheet	T100
Drawing Sheer	T101

DANE COUNTY - JCO / NIP SECURITY UPGRADES

CONSTRUCTION DRAWINGS

April 13, 2021

ARCHITECTURAL DRAWINGS

- G001 COVER SHEET, SHEET INDEX, SEALS, LOCATION MAP
- G002 LIFE SAFETY AND CODE SUMMARY
- G003 GENERAL DRAWING INFORMATION
- AD101 DEMO ENLARGED FLOOR PLANS
- AD201 DEMO REFLECTED CEILING PLANS
- A100 SITE AND EXTERIOR DRAWINGS
- A101 JCO/ DWO ENLARGED FLOOR PLANS
- A102 NIP ENLARGED FLOOR PLANS
- A201 REFLECTED CEILING PLANS
- A401 INTERIOR ELEVATIONS
- A402 INTERIOR ELEVATIONS
- A800 ROOM FINISH SCHEDULE AND DOOR SCHEDULE

FIRE SUPPRESSION DRAWINGS

- FXD102 NIP ENLARGED FIRE SUPPRESSION DEMOLITION PLAN
- FX102 NIP ENLARGED FIRE SUPPRESSION PLAN

MECHANICAL DRAWINGS

- HD101 JCO ENLARGED HVAC DEMOLITION PLAN
- HD102 NIP ENLARGED HVAC DEMOLITION PLAN
- H101 JCO ENLARGED HVAC PLAN
- H102 NIP ENLARGED HVAC PLAN
- H500 HVAC DETAILS, NOTES, SCHEDULES, AND SYMBOLS

ELECTRICAL DRAWINGS


- ED101 JCO ENLARGED ELECTRICAL DEMOLITION PLANS
- ED102 NIP ENLARGED ELECTRICAL DEMOLITION PLAN
- E101 JCO ENLARGED LIGHTING FLOOR PLAN
- E102 NIP ENLARGED LIGHTING FLOOR PLAN
- E201 JCO ENLARGED POWER FLOOR PLAN
- E202 NIP ENLARGED POWER FLOOR PLAN
- E500 ELECTRICAL LIGHTING SCHEDULES AND CONTROLS
- E510 ELECTRICAL DETAILS
- E520 ELECTRICAL NOTES AND SYMBOLS

FIRE ALARM DRAWINGS

- FA101 ENLARGED FIRE ALARM PLANS
- FA500 FIRE ALARM SCHEDULES AND DETAILS

TECHNOLOGY DRAWINGS

- T100 OVERALL TECHNOLOGY FLOOR PLAN
- T101 JCO/DWO ENLARGED TECHNOLOGY PLAN
- T102 NIP ENLARGED TECHNOLOGY PLAN
- T500 ACCESS CONTROL SCHEDULES AND DETAILS
- T510 TECHNOLOGY SCHEDULES AND DETAILS



SITE AERIAL

I hereby certify these plans and specifications were prepared by me or under my direct personal supervision and that I am a duly licensed professional architect under the laws of the state of Wisconsin.



301 N Broom St., Suite 100
Madison, WI 53703
P: 608-819-0260
F:

www.opnarchitects.com
All reports, plans, specifications, computer files, field data, notes and other documents and instruments prepared by OPN Architects, Inc. are instruments of service that remain the property of OPN Architects, Inc. OPN Architects, Inc. shall retain all common law, statutory and other reserved rights, including the copyright therein.
© 2021 OPN Architects, Inc.

Sheets covered by this seal: Listed As "Architectural"

I hereby certify this engineering document was prepared by me or under my direct personal supervision and that I am a duly licensed professional engineer under the laws of the state of Wisconsin.

Owner

DANE COUNTY
Department of Public Works, Highway & Transportation, Engineering Division
1919 Alliant Energy Center Way
Madison, Wisconsin 53713

Sheets covered by this seal: Listed As "Mechanical, Plumbing"

I hereby certify this engineering document was prepared by me or under my direct personal supervision and that I am a duly licensed professional engineer under the laws of the state of Wisconsin.

Project
JCO/ NIP LOBBY SECURITY UPDATES
1819 Aberg Avenue and
1227 North Sherman Avenue
Madison, WI 53704

Consultants

MEP Engineer

DESIGN ENGINEERS
437 South Yellowstone Drive
Madison, Wisconsin 53719-1042
608.424.8815

Sheets covered by this seal: Listed As "Electrical"

Key Plan

Revision	Description	Date
AD 1	ADDENDUM #1	05/22/21

OPN Project No.
20635000

Sheet Issue Date
CONSTRUCTION DRAWINGS 04/13/2021

Sheet Name
COVER SHEET, SHEET INDEX, SEALS, LOCATION MAP


Sheet Number

G001


DEMOLITION LEGEND

- INDICATES EXISTING 1 HR FIRE BARRIER
- /// DENOTES AREA OF COMPLETE REMOVAL OF AN EXISTING BUILDING ELEMENT


- GENERAL NOTES**
- IDENTIFICATION AND/OR ABATEMENT OF HAZARDOUS MATERIALS IS NOT PART OF THIS SCOPE OF WORK. IF ASBESTOS OR OTHER HAZARDOUS MATERIALS ARE ENCOUNTERED, THE CONTRACTOR SHALL NOTIFY THE OWNER IMMEDIATELY.
 - REMOVE LOOSE PAINT AND MISCELLANEOUS HANGING OBJECTS FROM WALLS AND CEILINGS AT ALL AREAS TO RECEIVE NEW FINISHES.
 - OPENING IN THE EXISTING STRUCTURE SMALLER THAN 12" IN ANY DIRECTION ARE NOT IDENTIFIED ON THESE DRAWINGS. SUB-CONTRACTORS SHALL BE RESPONSIBLE FOR PROVIDING OPENINGS SMALLER THAN 12" AS REQUIRED FOR INSTALLATION OF THEIR WORK.
 - OPENINGS IN THE EXISTING STRUCTURE SHALL NOT BE MADE WITHOUT PRIOR APPROVAL OF THE STRUCTURAL ENGINEER.
 - PATCH AND REPAIR ALL EXISTING FLOOR SLABS AND WALL SURFACES DAMAGED FROM DEMOLITION OR PRIOR USE.
 - PATCH ALL AREAS OF ELECTRICAL AND MECHANICAL DEMOLITION THAT WILL NOT BE REUSED.
 - CONTRACTOR TO FIELD VERIFY ALL EXISTING DIMENSIONS AND CONDITIONS. IN THE EVENT OF A DISCREPANCY BETWEEN THE DRAWINGS AND THE EXISTING CONDITIONS, NOTIFY THE ARCHITECT BEFORE PROCEEDING.
 - DO NOT REMOVE ANY ITEMS WHICH JEOPARDIZE THE STRUCTURAL INTEGRITY OF THE BUILDING. IF HIDDEN ELEMENTS OR DETERIORATED ELEMENTS ARE ENCOUNTERED, NOTIFY THE ARCHITECT IMMEDIATELY.
 - EXISTING BUILDING IS TO REMAIN WEATHER-TIGHT DURING ALL DEMOLITION ACTIVITIES.
 - REFER TO CONSULTANT DRAWINGS FOR ADDITIONAL DEMOLITION OF OTHER DISCIPLINES.
 - PROTECT ALL ADJACENT AREAS AND ITEMS TO REMAIN DURING DEMOLITION/CONSTRUCTION. REPAIR/REPLACE ALL ITEMS DAMAGED DURING CONSTRUCTION.
 - EXISTING BUILDINGS CONDITIONS SHOWN ON THESE DRAWINGS ARE DERIVED FROM DRAWINGS OF THE ORIGINAL BUILDING AND FROM LIMITED FIELD OBSERVATION.
 - INDICATED EXISTING BUILDING CONDITIONS ARE ASSUMED TO BE REPRESENTATIVE OF THE ACTUAL CONSTRUCTION OF THE BUILDING. LOCAL CONDITIONS MAY VARY.
 - THE CONTRACTOR SHALL PROVIDE AND MAINTAIN ADDITIONAL MEANS OF EGRESS AS NEEDED AS A RESULT OF CONSTRUCTION SEQUENCING AND/OR REGULATORY REQUIREMENTS.



2 DEMO NIP FLOOR PLAN
1/8" = 1'-0"



3 OVERALL DEMO PLAN
1/32" = 1'-0"




1 DEMO JCO FLOOR PLAN
1/8" = 1'-0"


Key Plan

Revision	Description	Date
AD 1	ADDENDUM #1	05/22/21


- GENERAL NOTES**
1. DIMENSIONS ARE MEASURED FACE-OF-FINISH OR ROUGH MASONRY OPENING UNLESS NOTED OTHERWISE - TYPICAL FOR ALL DRAWINGS.
 2. FIELD VERIFY ALL DIMENSIONS AND EXISTING CONDITIONS - TYPICAL FOR ALL DRAWINGS.
 3. IN THE EVENT OF A DISCREPANCY BETWEEN ARCHITECTURAL AND CONSULTANT DRAWINGS, NOTIFY ARCHITECT IMMEDIATELY PRIOR TO COMMENCING WORK - TYPICAL FOR ALL DRAWINGS.
 4. ALL PENETRATIONS IN FIRE RATED FLOORS AND WALLS MUST BE SEALED WITH APPROPRIATE FIRESTOPPING SYSTEM.
 5. PATCH AND REPAIR EXISTING FLOOR SLABS AND WALL SURFACES DAMAGED FROM DEMOLITION.
 6. PATCH AND REPLACE ANY SOILED OR DAMAGED CARPET TILES.




5 OVERALL PLAN
 1/32" = 1'-0"



2 DOJ FLOOR PLAN
 1/8" = 1'-0"




3 ENLARGED DWD DESK PLAN
 1/4" = 1'-0"




4 ENLARGED BENEFITS DESK PLAN
 1/4" = 1'-0"

Key Plan


Revision	Description	Date
AD 1	ADDENDUM #1	05/22/21




14 GLASS TO COUNTERTOP SECTION DETAIL
3/4" = 1'-0"




15 TYPICAL STATION SECTION
3/4" = 1'-0"




16 SECTION AT DESK NORTH
3/4" = 1'-0"




17 CSS CASEWORK SECTION
3/4" = 1'-0"




18 GLASS PARTITION DETAIL
3/4" = 1'-0"




13 ADA STATION SECTION
3/4" = 1'-0"




12 BENEFITS NORTH ELEVATION 1/4" = 1'-0"
11 BENEFITS FRONT ELEVATION 1/4" = 1'-0"
10 CSS/ SECURITY FRONT ELEVATION 1/4" = 1'-0"




5 PRINTER HUB EAST ELEVATION
1/4" = 1'-0"




6 PRINTER HUB WEST ELEVATION
1/4" = 1'-0"




7 PLAN DETAIL AT DIVIDER (TYP)
3/4" = 1'-0"




8 PARTITION HALF WALL ELEVATION (TYP BOTH SIDES)
1/4" = 1'-0"




9 PRINTER HUB SOUTH ELEVATION
1/4" = 1'-0"




1 DWD DESK NORTH ELEVATION
1/4" = 1'-0"




2 PRINTER CASEWORK ELEVATION
1/4" = 1'-0"



3 DWD DESK FRONT ELEVATION
1/4" = 1'-0"



4 DWD PUBLIC PRINTER ELEVATION
1/4" = 1'-0"



19 PARTITION HALF WALL SECTION
3/4" = 1'-0"

From Room: Name	From Room: Number	DOOR NUMBER	PANEL		Door Panel Type	PANEL				FRAME		HARDWARE SET	REMARKS
			WIDTH	HEIGHT		PANEL 1 WIDTH	PANEL 2 WIDTH	PANEL MATERIAL	PANEL FINISH	MATERIAL	FINISH		
NIP CORRIDOR	122	107A	3'-0"	7'-0"	F	3'-0"		HM	P-3	HM	P-3	3.0	1
NIP CORRIDOR	122A	107B	3'-0"	7'-0"	F	3'-0"		WD	WD-1B	HM	P-3	6.0	
NIP CORRIDOR	122A	107D.1	3'-0"	7'-0"	F	3'-0"		WD	WD-1B	HM	P-3	6.0	
NIP CORRIDOR	112	112A	3'-0"	7'-0"	F	3'-0"		HM	P-3	HM	P-3	3.0	1,3
NIP CORRIDOR	112	112B	3'-0"	7'-0"	F	3'-0"		WD	WD-1B	HM	P-3	7.0	
NIP CORRIDOR	122	122A	6'-0"	7'-0"	HG	3'-0"	3'-0"	HM	P-3	HM	P-3	4.0	1
NIP CORRIDOR	122B	122B	6'-0"	7'-0"	HG	3'-0"	3'-0"	HM	P-3	HM	P-3	4.0	1
JCO CHILDCARE	J057	J057B	3'-0"	7'-0"	ALUM	3'-0"		ALUM	MATCH EXIST.	ALUM	MATCH EXIST.	2.0	2
JCO CHILDCARE	J057	J057E.1	EXISTING	EXISTING	EX	EXISTING		EX	EX	EX	EX	8.0	
JCO CHILDCARE	J057	J057E.2	EXISTING	EXISTING	EX	EXISTING		EX	EX	EX	EX	8.0	
JCO JOB INFORMATION CENTER	J065	J064A	4'-0"	7'-0"	QG1	3'-0"	1'-0"	WD	WD-1A	HM	P-3	5.0	3
JCO BENEFITS/ SECURITY/CSS	J065A	J065A.1	3'-0"	7'-0"	F	3'-0"		WD	WD-1A	HM	P-3	3.0	3
JCO BENEFITS/ SECURITY/CSS	J065A	J065A.2	3'-0"	7'-0"	F	3'-0"		WD	WD-1A	HM	P-3	3.0	3
JCO ALCOVE	J065B	J065B	3'-0"	7'-0"	F	3'-0"		WD	WD-1A	HM	P-3	3.0	3
JCO DWD DESK	J065C	J065C.1	3'-0"	7'-0"	F	3'-0"		WD	WD-1A	HM	P-3	3.0	4
JCO DWD DESK	J065C	J065C.2	3'-0"	7'-0"	F	3'-0"		WD	WD-1A	HM	P-3	3.0	3
JCO BENEFITS/ SECURITY/CSS	J065A	J065E.1	6'-0"	7'-0"	QG2	3'-0"	3'-0"	WD	WD-1A	EX	EX	1.0	3,5
JCO BENEFITS/ SECURITY/CSS	J065A	J065E.2	3'-0"	7'-0"	QG	3'-0"		WD	WD-1A	EX	EX	3.0	3,5
JCO JOB INFORMATION CENTER	J065	J065E.3	6'-0"	7'-0"	QG2	3'-0"		WD	WD-1A	EX	EX	1.0	3,5
JCO JOB INFORMATION CENTER	J065	J065E.4	EXISTING	EXISTING	EX	EXISTING		EX	EX	EX	EX	8.0	


- NOTES:**
- ALTERNATE NO. 3: PROVIDE ALTERNATE PRICE FOR LEVEL 3 BULLET RESISTANT HM DOOR, GLAZING (WHERE SHOWN) AND FRAME IN LIEU OF STANDARD HM DOOR AND FRAME.
 - PANIC HARDWARE - EXIT ONLY. FINISHES TO MATCH EXISTING
 - KEY CARD ACCESS - REFER TO AND COORDINATE WITH DRAWING SHEETS T101 AND T102 FOR CARD READER LOCATIONS.
 - EXIT ONLY
 - NEW DOOR IN EXISTING HM FRAME.

- GENERAL NOTES:**
- ALL DOOR LEVERS TO BE ADA ACCESSIBLE
 - ALL DOORS TO HAVE SURFACE MOUNTED CLOSER AND STANDARD HINGES- CLOSURES TO BE MOUNTED ON INSIDE OF ROOM.

- GENERAL NOTES**
- SEE FRAME PLANS AND INTERIOR ELEVATIONS FOR DIMENSIONAL SIZES WITH MATERIALS OF FRAMES.
 - PREPARE DOOR AND FRAME FOR PAINT - BONDO DENTS AND SAND SCRATCHES SMOOTH.
 - PAINT ALL HOLLOW METAL DOORS AND FRAMES AS SCHEDULED.

- GENERAL NOTES**
- DIMENSIONS ARE MEASURED FACE-OF-FINISH TO FACE-OF-FINISH OR ROUGH MASONRY OPENING UNLESS NOTED OTHERWISE - TYPICAL FOR ALL DRAWINGS.
 - FIELD VERIFY ALL DIMENSIONS AND EXISTING CONDITIONS - TYPICAL FOR ALL DRAWINGS.
 - IN THE EVENT OF A DISCREPANCY BETWEEN ARCHITECTURAL AND CONSULTANT DRAWINGS, NOTIFY ARCHITECT IMMEDIATELY PRIOR TO COMMENCING WORK - TYPICAL FOR ALL DRAWINGS.
 - ALL PENETRATIONS IN FIRE RATED FLOORS AND WALLS MUST BE SEALED WITH APPROPRIATE FIRESTOPPING SYSTEM.
 - PATCH AND REPAIR EXISTING FLOOR SLABS AND WALL SURFACES DAMAGED FROM DEMOLITION.
 - PATCH AND REPLACE ANY SOILED OR DAMAGED CARPET TILES

- GENERAL NOTES**
- REFER TO FINISH PLANS, REFLECTED CEILING PLANS, AND ELEVATIONS FOR LOCATION AND EXTENT OF FINISHES.
 - PAINT ALL INTERIOR MISCELLANEOUS METAL GRILLES, LOUVERS ACCESS PANELS, PIPES AND CONDUIT EXPOSED TO VIEW TO MATCH THE WALLS IN WHICH THEY OCCUR UNLESS OTHERWISE NOTED.
 - ALL EXPOSED DRYWALL TO RECEIVE PAINT UNLESS NOTED OTHERWISE.
 - PAINT ALL REVEALS TO MATCH THE WALLS IN WHICH THEY OCCUR.
 - PAINT ALL LIGHT FIXTURE TRIMS AND FLANGES OF LINEAR DIFFUSERS TO MATCH THE COLOR TO THE CEILING IN WHICH THEY OCCUR.
 - PAINT ALL EXPOSED SPEAKERS WITH A PAINT THAT WILL NOT DEGRADE THEIR ACOUSTICAL PERFORMANCE IN A COLOR TO MATCH THE WALL OR CEILING IN WHICH THEY OCCUR.
 - ALL PAINTED HOLLOW METAL DOORS AND FRAMES TO BE PAINTED TO MATCH THE COLOR OF THE WALL IN WHICH THEY OCCUR U.N.O.
 - REFER TO ROOM FINISH SPECIFICATION FOR CARPET PATTERN AND DIRECTION & FOR ROOM FINISH SPECIFICATIONS AND ADDITIONAL INFORMATION.
 - ALL FLOORING MATERIAL TRANSITIONS, TERMINATION AND SEAM LOCATIONS ARE TO BE CENTERED UNDER DOOR LEAFS IN CLOSED POSITION U.N.O.
 - EXTEND FLOORING INTO TOE SPACES, DOOR REVEALS, CLOSETS AND SIMILAR OPENINGS U.N.O.
 - PROVIDE FLOORING TRANSITION STRIPS AT FLOOR MATERIAL CHANGES. COORDINATE FLOORING TRANSITION MATERIAL, PROFILE, AND COLOR WITH ARCHITECT PRIOR TO INSTALLATION-REFER TO DETAIL DRAWINGS FOR DESIGN INTENT.
 - REFER TO SHEET A002 FOR TYPICAL MOUNTING HEIGHTS.
 - POWER AND DATA LOCATIONS ARE TO BE COORDINATED IN THE FIELD WITH FINAL FURNISHING PLANS PRIOR TO INSTALLATION OF BOXES, FITTINGS, AND RACEWAYS.




ROOM NAME	Number	FLOOR		WALL FINISH				CEILING	NOTES
		FINISH	BASE	NORTH	EAST	SOUTH	WEST		
Level 1									
JCO CHILDCARE	J057	N/A	N/A	TOUCH UP AS NEEDED	N/A	N/A	N/A	E.T.R.	
JCO CORRIDOR	J054	E.T.R.	E.T.R.	N/A	N/A	N/A	N/A	E.T.R.	
JCO JOB CENTER WAITING	J064	E.T.R.	E.T.R.	EXISTING	WPC-1/ P-1 ABOVE	N/A	SEE PLAN	E.T.R.	3
JCO ALCOVE	J065B	E.T.R.	E.T.R.	N/A	P-1	P-1	P-1	E.T.R.	3
JCO DWD DESK	J065C	E.T.R.	E.T.R.	P-1	P-1	P-1	P-1	E.T.R.	3
JCO BENEFITS/ SECURITY/CSS	J065A	E.T.R.	E.T.R.	SEE ELEVATIONS	P-1	P-1	P-1	E.T.R.	3
JCO JOB INFORMATION CENTER	J065	E.T.R.	E.T.R.	P-1	P-1	P-1	P-1	E.T.R.	3
NIP RECEPTION CENTER	107F	CPT-2	RB-1	P-1	P-1	P-1	P-1	ACT-1	
NIP CORRIDOR	122	CPT-3	RB-1	SEE ELEVATIONS	P-1	P-1	P-1	E.T.R.	
NIP CORRIDOR	122A	E.T.R.	E.T.R.	P-2 TOUCH UP AS NEEDED	P-2	P-2	P-2 TOUCH UP AS NEEDED	E.T.R.	1,2,3
NIP CORRIDOR	122B	E.T.R.	E.T.R.	P-2	N/A	N/A	N/A	E.T.R.	1,2,3
NIP CORRIDOR	112	E.T.R.	E.T.R.	P-2 TOUCH UP AS NEEDED	N/A	N/A	N/A	E.T.R.	1
NIP STAFF OFFICE	110	N/A	N/A	N/A	N/A	TOUCH UP AS NEEDED	N/A	E.T.R.	
NIP CORRIDOR	107	CPT-2	RB-1	P-1	P-1	P-1	P-1	E.T.R.	
NIP MAIL	107D	CPT-2	RB-1	P-2 TOUCH UP AS NEEDED	P-2	P-2	P-2	E.T.R.	
NIP WORK AREA	107A	CPT-2	RB-1	P-1	P-1	P-1	P-1	ACT-1	
NIP VESTIBULE	101	N/A	N/A	N/A	N/A	N/A	N/A	E.T.R.	

- NOTES:**
- ALTERNATE NO. 1: INSTALL NEW VCT-1 AND RB-1 INFILL CEILING TILE AND GRID AS NECESSARY AT NEW PARTITIONS.
 - INFILL CEILING TILE AND GRID AS NECESSARY AT NEW PARTITIONS.
 - NEW WALL BASE TO MATCH EXISTING AT NEW PARTITIONS, NEW FLOORING INFILL AS NECESSARY TO MATCH EXISTING.

FINISH SPECIFICATIONS	PAINT	PLASTIC LAMINATE	DECORATIVE LAMINATED GLAZING
FLOORING			BASIS OF DESIGN:
CPT-1 (NOT USED)	P-1 MANUFACTURER: BENJAMIN MOORE COLOR: 1534 ROBED EGGSHELL FINISH:	PLAM-1 MANUFACTURER: WILSONART COLOR: SHADOW ZEPHYR COLOR NUMBER: 4857-60	MANUFACTURER: 3FORM STYLE: PRESSED GLASS PATTERN: GRAPHIC PATTERN COLOR SCALE: BRANCHED COLOR: W04 FLURRY 50%
CPT-2 MANUFACTURER: MILLIKEN STYLE: BASS LINE SIZE: 24X24 COLOR: 83127 VINLY RANDOM INSTALLATION:	P-2 MATCH EXISTING NIP WALL PAINT	PLAM-2 MANUFACTURER: WILSONART STYLE: COMPACT 535 COLOR: WEATHERED BRONZE COLOR NUMBER: Y0384-60 THICKNESS: 3/8" - DOUBLE FACED BOARD NOTES: EACH STRAIGHT RUN TO BE SINGLE SEAMLESS SHEET. CORNERED OUTSIDE	ACOUSTICAL CEILING
CPT-3 MANUFACTURER: MILLIKEN STYLE: OBEX TILE CUTX / DRIFT SIZE: 24X24 COLOR: DTX5-27 GREY INSTALLATION: ASHLAR	WPC-1 MANUFACTURER: WOLF GORDON STYLE: RAMPART COLOR: KEREN / GREIGE	PLAM-3 MANUFACTURER: ARBORITE STYLE: W-48 EV COLOR: RIFT NATURAL OAK	ACT-1 MANUFACTURER: USG STYLE: ECLIPSE ACOUSTICAL PANEL SIZE: 2' X 4' EDGE: FINELINE GRID: 9/16" CENTRICITEE COLOR: WHITE GRID COLOR: WHITE
VCT-1 MANUFACTURER: ARMSTRONG STYLE: PREMIUM EXCELON SIZE: 12" X 12" COLOR: PEWTER 6C908	WOOD	PLAM-4 MANUFACTURER: WILSONART COLOR: WEATHERED BRONZE COLOR NUMBER: Y0384-60	
WB-1 MANUFACTURER: JOHNSONITE STYLE: TRADITIONAL WALL BASE COLOR: 63 BURNT UMBER B SIZE: 4" HIGH PROFILE: STRAIGHT NOTE: ROLLED GOODS ONLY	WD-1A SPECIES: RED OAK MATCH EXISTING DOORS AT JCO PER APPROVED SAMPLES	PLAM-5 MANUFACTURER: WILSONART STYLE: POTTERS CLAY COLOR NUMBER: 5011K-22	
	WD-1B SPECIES: RED OAK MATCH EXISTING DOORS AT NIP PER APPROVED SAMPLES	SOLID SURFACE	
	WD-2 SPECIES: RED OAK BLACK STAIN PER APPROVED SAMPLE	SLD-1 MANUFACTURER: WILSONART STYLE: QUARTZ SELECT COLOR: Q617 ABLEINE THICKNESS: 2CM	

KEYED NOTES	
E-2	TYPICAL EXISTING CIRCUITING TO BE FIELD VERIFIED. ALL EXISTING CIRCUITS THAT WERE REMOVED DURING DEMOLITION MAY BE REUSED. PROVIDE NEW BREAKERS TO MATCH EATON PANELS AS NECESSARY. NEW CIRCUIT DESIGNATIONS (LETTERS) SHOWN ONLY TO CONVEY DESIGN INTENT FOR DEVICES ON THE SAME CIRCUIT. USE NEXT AVAILABLE CIRCUIT IN EXISTING PANELS (LPA, LPB, LPC, LPD, PPA, PPC FOR NEW CIRCUITS. SERVE SAME GENERAL AREA CURRENTLY SERVED BY EACH PANEL.
E-5	FINAL LOCATION OF POWER POLES TO BE COORDINATED BEFORE INSTALLATION WITH OWNER AND OWNERS FURNITURE SUPPLIER.



1 JCO ELECTRICAL POWER PLAN
1/8" = 1'-0"

NEW WORK KEY	
	EXISTING
	NEW / REVISED
	EXISTING EQUIPMENT
	NEW / REVISED EQUIPMENT

RECEPTACLE KEY	
TR	INDICATES TAMPER RESISTANT (SAFETY TYPE) RECEPTACLE
GF-I	INDICATES GROUND FAULT INTERRUPTER RECEPTACLE
TVSB	INDICATES TRANSIENT VOLT SURGE SUPPRESSOR RECEPTACLE
IG	INDICATES ISOLATED GROUND RECEPTACLE
WP	INDICATES RECEPTACLE WITH WEATHERPROOF BOX / FLUPOVER
WPD	INDICATES RECEPTACLE WITH WEATHERPROOF BOX / CONDUIT AND PLUG COVER
#	NUMBER INDICATES PANEL CIRCUIT NUMBER
##"	DIMENSION INDICATES HEIGHT TO CENTER OF RECEPTACLE ABOVE FINISH FLOOR; ##" IF NOT SHOWN
USB	INDICATES USB TYPE RECEPTACLE

Key Plan


Revision	Description	Date
ADD	ADDENDUM #1	5/12/2021

KEYED NOTES	
T-1	REMOVE ALL COAX, ANALOG CAMERAS AND EXISTING VMS EQUIPMENT AFTER NEW DATA CABLES, IP CAMERAS AND VMS EQUIPMENT IS INSTALLED AND OPERATIONAL.

Owner
DANE COUNTY
Department of Public Works, Highway & Transportation, Engineering Division
1919 Alliant Energy Center Way
Madison, Wisconsin 53713

Project
JCO/ NIP LOBBY SECURITY UPDATES
1819 Aberg Avenue and
1227 North Sherman Avenue
Madison, WI 53704

Consultants
MEP Engineer
DESIGN ENGINEERS
437 South Yellowstone Drive
Madison, Wisconsin 53719-1042
608.424.8815




1 OVERALL TECHNOLOGY FLOOR PLAN
1/16" = 1'-0"


Key Plan

Revision	Description	Date
ADD	ADDENDUM #1	5/12/2021

KEYED NOTES



1 JCO/DWD ENLARGED TECHNOLOGY PLAN
1/8" = 1'-0"



2 SOUTHEAST EXTERIOR TECHNOLOGY PLAN
1/8" = 1'-0"

ALL DEVICES ON THIS SHEET SHALL GO BACK TO ROOM J070

DEMO/NEW WORK KEY

- EXISTING
- - - - TO BE REMOVED/REVISED
- NEW / REVISED

Revision	Description	Date
ADD	ADDENDUM #1	5/12/2021