



# DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive  
Joseph T. Parisi

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713  
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director  
Gerald J. Mandli

August 4, 2016

## ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

**RFB NO. 316031 - ADDENDUM NO. 1**

**CONSTRUCT GENERATOR BUILDING**

**DANE COUNTY LANDFILL SITE #1**

**6718 EAST VERONA AVENUE**

**VERONA, WISCONSIN**

---

**BIDS DUE**: Thursday, August 11, 2015, 2:00 PM.  
DUE DATE AND TIME **ARE NOT** CHANGED BY THIS ADDENDUM

---

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. **Bidders must acknowledge this addendum on the bid form.**

### PLEASE MAKE THE FOLLOWING CHANGES:

#### 1. Section 01 00 00 – General Requirements

- a. Article 1.2 - SUMMARY OF WORK, Paragraph A:  
CHANGE: “Project Description: Perform the Work as specified and detailed in Construction Documents package. Contractor to provide construction services for a pre-engineered metal building of approximately 1,056 square feet including associated site work, concrete work, and HVAC work.” TO READ: “Project Description: Perform the Work as specified and detailed in Construction Documents package. Contractor to provide construction services for a pre-engineered metal building of approximately 1,104 square feet including associated site work, concrete work, and HVAC work.”
- b. Article 1.17 – QUALITY ASSURANCE / QUALITY CONTROL OF INSTALLATION, Paragraph A:  
CHANGE: “Monitor quality control over suppliers, manufacturers, Products, services, site conditions, and workmanship, to produce work of specified quality.” TO READ: “County to monitor quality control over suppliers, manufacturers, products, services, site conditions, and workmanship, to produce work of specified quality.”
- c. Article 1.17 – QUALITY ASSURANCE / QUALITY CONTROL OF INSTALLATION, Paragraph B:  
CHANGE: “Comply fully with manufacturers' instructions.” TO READ: “Contractor to comply fully with manufacturers' instructions.”
- d. Article 1.17 – QUALITY ASSURANCE / QUALITY CONTROL OF INSTALLATION, Paragraph C:  
CHANGE: “Comply with specified standards as minimum quality for the Work except when more stringent tolerances, codes, or specified requirements indicate higher standards or more precise workmanship.” TO READ: “Contractor to comply with

specified standards as minimum quality for the Work except when more stringent tolerances, codes, or specified requirements indicate higher standards or more precise workmanship.”

- e. Article 1.23 – Occupancy During Construction and Conduct of Work, Paragraph E: CHANGE: “Contractor [is, is not] responsible for providing & maintaining temporary toilet facilities.” TO READ: “Contractor is responsible for providing & maintaining temporary toilet facilities.”

**2. Muffler Weight**

Change ALL notes on drawings from “Contractor to design roof and building supports to accommodate additional dead load of muffler unit” to “Contractor to design roof and building supports to accommodate additional dead load of two (2) muffler units of approximately 425 lbs. each”.

**3. Sheet HV101 – Floor Plan HVAC**

In equipment room with PTAC-1 refer to **Sheet 9 of 9 - Floor Plan** for correct location and orientation of 36" exterior exit walk door.

If any additional information about this Addendum is needed, please contact John Welch at (608) 516-4154, or [Welch@countyofdane.com](mailto:Welch@countyofdane.com).