



DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive
Kathleen M. Falk

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director
Gerald J. Mandli

Monday, February 14, 2011

ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

RFB NO. 1 - ADDENDUM NO. 1

CONDENSER WATER PIPE REPLACEMENT

CITY-COUNTY BUILDING

BIDS DUE: MONDAY, FEBRUARY 21, 2011, 2:00 PM. DUE DATE AND TIME ARE CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

PLEASE MAKE THE FOLLOWING CHANGES:

1. Bid Due Date:

- a. Bid Due Date will be extended to Monday, February 21, 2011, at 2:00 PM.

2. Clarification:

- a. Q: Is the contractor only responsible for dust barriers on 4th Floor?
A: Contractor is responsible for providing temporary partitions at any location that will affect building occupants. Partitions must prevent the infiltration of dust, smoke, and fumes to areas accessible to building occupants. Areas of Work that do not require these partitions include the sub-basement, penthouse and roof.

If any additional information about this Addendum is needed, please call Steve Richards at 608/219-6339, Richards.steven@countyofdane.com

Sincerely,
Steve Richards
Project Engineer

Enclosures:
N/A