



**DANE COUNTY DEPT. OF  
PUBLIC WORKS, HIGHWAY &  
TRANSPORTATION**

1919 Alliant Energy Center Way  
Madison, Wisconsin 53713  
Office: 608/266-4018 ♦ Fax: 608/267-1533  
Public Works Engineering Division

# **ADDENDUM**

December 12, 2019

**ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS**

**RFB NO. 319034 - ADDENDUM NO. 3**

**FOURTH FLOOR OFFICES REMODEL, SUITES 418, 419 & 425**

---

**BIDS DUE: TUESDAY, DECEMBER 17, 2019, 2:00 PM. DUE DATE AND  
TIME ARE NOT CHANGED BY THIS ADDENDUM.**

---

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

**PLEASE MAKE THE FOLLOWING CHANGES:**

**PLEASE NOTE THE FOLLOWING CONTRACTOR SUBMITTED QUESTIONS:**

**Q1:** For the Tele/Data work, do the existing conduit stubs need to be replaced w/ 1 1/4" conduit stubs?

**A1:** The drawings & specs call for 1-1/4" raceways & the project should be bid that way.

If any additional information about this Addendum is needed, please call Scott Carlson at 608/266-4179, carlson.scott@countyofdane.com.

Sincerely,  
*Scott Carlson*  
Project Manager

Enclosures:  
N/A

H:\Shared\ENGINEERING DIVISION\Scott Carlson\319034 - CCB 4th Flr Offices Remodel\03 - Addendum\319034-Addm3.docx