



# DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive  
Kathleen M. Falk

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713  
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director  
Gerald J. Mandli

October 13, 2009

## ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

**RFB NO. 309025 - ADDENDUM NO. 3**

**GAS COMPRESSOR BUILDING**

---

**BIDS DUE:** THURSDAY, OCTOBER 15, 2009, 2:00 PM. DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.

---

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and Addenda 1-2, and is hereby made a part of the RFB. **Acknowledge all addenda on your Bid Form.**

### PLEASE MAKE THE FOLLOWING CHANGES:

**1. Equipment Piping**

Contractor is NOT required to provide explosion proof gaskets where piping penetrates the building walls. At these locations, Contractor must caulk around the pipes to provide a weather tight seal.

**2. Product Substitutions**

The following additional requests for product substitutions have been approved. Contractor must still verify that the specific product/system that they are proposing meets all requirements of the specification package.

Building Manufacturer/Supplier: Metallic Building Company is approved.

Insulation Manufacturer/Supplier: GBP Silvercote is approved.

If any additional information about this Addendum is needed, please call John Welch at 608/267-8815, [welch@co.dane.wi.us](mailto:welch@co.dane.wi.us).

Enclosures: NA