



**DANE COUNTY DEPT. OF
PUBLIC WORKS, HIGHWAY &
TRANSPORTATION**

1919 Alliant Energy Center Way
Madison, Wisconsin 53713
Office: 608/266-4018 ♦ Fax: 608/267-1533
Public Works Engineering Division
Public Works Solid Waste Division

ADDENDUM 2

January 18, 2018

ATTENTION ALL REQUEST FOR [BID, PROPOSAL (RFB, RFP)] HOLDERS

RFB NO. 317034 - ADDENDUM NO. 2

INFORMATION MANAGEMENT OFFICE REMODEL

BIDS DUE: Tuesday, January 23, 2018, 2:00 PM. DUE DATE AND
TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

PLEASE MAKE THE FOLLOWING CHANGES:

1. Section 09 69 00 Access Flooring

Section Title: 2.1 Manufacturers, A.

Add: "3. Approved equal by Camino Modular Building Systems."

2. Sheet E205 Power Plan

1. Clarify: the correct location for the relocated transformer is along the south wall between rooms 530 and 526. Delete the location shown between the MGB and rack 6.
2. Clarify: the partly obscured note applied to the figure eight array above the racks is to read " PROVIDE 4" BY 18" WELDED WIRE CABLE TRAY ABOVE RACKS."
3. Clarify: the partly obscured keyed note applied to the Eco aisle grouping is keyed note 16.
4. Add: to keyed note 16 "This contractor is to provide the racks and Eco aisle environmental enclosure."

3. Sheet E401 Electrical Schedules

Add new Sheet E401, issued with this Addendum.

If any additional information about this Addendum is needed, please call Ryan Shore at 608/266-4475, shore@countyofdane.com.

Sincerely,
Ryan Shore
Project Manager

Enclosures:
Sheet E401 Fixture Schedule

LIGHT FIXTURE SCHEDULE

TAG	LAMP DATA		DESCRIPTION	LIGHTING FIXTURE		MOUNT	CEILING TYPE	VOLT	SEE NOTE
	NO	TYPE		MAKE	CATALOG NO				
A	-	37W / 4220 LUMENS / 3500K LED	2 x 4 FLAT PANEL LED	MAXLITE	MLFP-24EP-40-35	RECESSED	GRID	120	
B	-	29W / 3360 LUMENS / 3500K LED	2 x 2 FLAT PANEL LED	MAXLITE	MLFP-22EP-30-35	RECESSED	GRID	120	
C	-	31W / 4961 LUMENS / 4000K LED	8" WIDE SUSPENDED DIRECT/INDIRECT	PEERLESS	BRM9L-H1-20/80-SSH-4T-R4-120-SCT-EZB-LP840-*48-ACG-C210	AIRCRAFT CABLE	-	120	
X	-	LED	EXIT LIGHT	LITHONIA	LQM-S-W-3-R-120/277-ELN-SD	TOP OR BACK	GRID	120	