



# DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive  
Joseph T. Parisi

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713  
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director  
Gerald J. Mandli

February 05, 2015

## ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

### RFB NO. 315001 - ADDENDUM NO. 2

#### ALLIANT ENERGY CENTER SITE LIGHTING IMPROVEMENTS

---

**BIDS DUE:** Tuesday, February 10, 2015, 2:00 PM. DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.

---

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB

#### PLEASE MAKE THE FOLLOWING CHANGES:

**1. Section 26 56 00**

Page 2 - Item 1.04: Change to the following:

“Luminaires shall be provided with a five (5) year manufacturer’s warranty covering LEDs and paint finish, manufacturer shall respond to site within ten (10) days’ notice of potential warranty issues by Alliant Energy Center Staff.”

Page 3 - Item 2.01.B: After the following paragraph, update series of potential approved substitutes.:

“The following series of alternate fixtures may be used provided luminaire meets or exceeds all requirements laid out in section 26 56 00 (Including the technical criteria listed for the specified Gleon units used as basis of design) and the construction documents. Bidder is responsible for ensuring specifications and requirements are met.

1. Lithonia Lighting D Series LED
2. GE Lighting Evolve LED Area Light
3. RAB, inc. ALED 2T Series
4. Cree OSQ Series
5. Cree Edge Series
6. Philips Gardco EcoForm
7. LSI Industries Aeromax”

Page 3 - Item 2.01.B: After this item, insert the following:

“C. Approved 12’ walkway lighting pole manufacturers, to meet above Hapco basis of design include:

1. Hapco
2. Valmont Industries
3. United Lighting Standards”

Page 5 - Item 2.02.C.4.e: Delete this item.

If any additional information about this Addendum is needed, please call Eric Urtes at 608-266-4798, [Urtes.Eric@countyofdane.com](mailto:Urtes.Eric@countyofdane.com).

Sincerely,

*Eric Urtes*

Project Manager

Enclosures: N/A

H:\Shared\Engineering Division\Eric Urtes\315001 - AEC Site Lighting Improvements\03 - Addendum\315001 Addendum 2.docx