



# DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive  
Joseph T. Parisi

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713  
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director  
Gerald J. Mandli

MARCH 1, 2012

## ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

### RFB NO. 312001 - ADDENDUM NO. 2

### BABCOCK AND LAFOLLETTE PARKS LOCKS AND DAMS RENOVATION PHASE 2 - LOCKS AND DAMS UPGRADES

---

**BIDS DUE:** MONDAY, MARCH 5, 2012, 10:00 AM. DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.

---

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

#### PLEASE MAKE THE FOLLOWING CHANGES:

**1. Construction Documents Project Manual Cover**

Change: “ Due Date / Time: **THURSDAY, MARCH 1, 2012 / 2:00 P.M.** ”,  
to: “ Due Date / Time: **MONDAY, MARCH 5, 2012 / 10:00 A.M.** ”.

**2. Legal Notice / Invitation To Bid**

Change: “ **2:00 P.M., THURSDAY, MARCH 1, 2012** ”,  
to: “ **10:00 A.M., MONDAY, MARCH 5, 2012** ”.

**3. The following were questions received during the Bidding period. Answers follow the questions. No further questions will be answered before the Bid Due Date.**

Q1: Specifications indicate black vinyl coated fence fabric. Is frame work vinyl coated?

A1: Fabric is to be vinyl coated Framework is galvanized.

Q2: Is MAPEI Planitop 12 repair mortar acceptable for concrete repairs?

A2: Material is acceptable for repairs 2inches deep or less. Concrete preparation must be in accordance with specifications and manufactures requirements.

Q3: Neither the drawings nor spec section 352016 “Miter Gates” provide any information as to what species of oak, nor treatment is required for the replacement wood miter and quoin seals on the new miter gates?

A3: White oak untreated.

Q4: Can rubber seals be used for quoin seal and mitre seal in lieu of white oak?

A4: Rubber seals are acceptable. Quoin seals should be Teflon coated. One miter seal of each pair should be Teflon coated.

Q5: Please clarify the specification requiring fluorocarbon on the rubber seals, is it only for the gate side seal (2"x5") or also the (2"x9") seal?

A5: Only the gate seal should be coated.

Q6: Is the existing pintle ball being reused?

A6: A new stainless steel pintel ball should be provided with a top radius to match the socket.

Q7: The new pintle socket is shown on the drawings (detail 8/S-7) as being bronze, however no specific metallurgical information is provided, please advise on the type of bronze required?

A7: Aluminum Bronze (C95400).

Q8: Are new PCs to be provided with the flow camera system?

A8: Owner will provide 2 PC at their remote location for the installation of camera software. The currently run Windows XP. PCs are not required to be provided at the project sites.

Q9: Is there a copy of the sign in sheet at the Pre-Bid that is available?

A9: Yes. It is attached to this Addendum.

Q10: Cofferdam notes on Sheets S-2.2 and S-4.2 say that the max. river closure is only 12'. Does this not include the lock chamber? In other words, could we cofferdam both the lock chamber and one of the stop log bays at the same time?

A10: No, do not plan to cofferdam the lock chamber and a dam bay. Maximum river closure is 12'.

If any additional information about this Addendum is needed, please call Rob Nebel at 608/267-0119, nebel@countyofdane.com.

Sincerely,

*Rob Nebel*

Project Engineer

Enclosures:

Pre-Bid Meeting Sign\_In Sheet

S:\PubWork\Shared\Engineering Division\Scott Carlson\312001 - BLT Locks Dams Ph.2 Construction\03 - Addendum\Ph.2-Add'm2.doc

02/14/12

Babcock and Lafollette Parks Locks and Dams Renovation  
Phase 2 - Locks & Dams Upgrades

Name	Company	Phone No.
Fran Reible	Daniels Construction	608-271-4800
AARON STAAB	STAAB CONSTRUCTION	715-387-8429
Rodger Bean	J.F. Brennan Co Inc	608-790-4824
Jeff Steiber	J.F. Brennan Co. Inc.	608 784-7173
Scott Luyum	Drax Inc	608 268-3468
Tony Ants	Terra Engineering	608-221-3501
MIKE HORNE	GRAEF	414-259-1500
JOE YAEGER	DANE COUNTY	
SCOTT CARLSON	" "	