



DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive
Joseph T. Parisi

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director
Gerald J. Mandli

May 12, 2016

ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

RFB NO. 315037- ADDENDUM NO. 1

ADMINISTRATION BUILDING RECLADDING AND REROOFING HENRY VILAS ZOO

BIDS DUE: THURSDAY, MAY 19, 2016 2:00 PM. DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. **Acknowledge this addendum on the Bid Form.**

CHANGES TO BIDDING REQUIREMENTS:

None

CHANGES TO SPECIFICATIONS:

1. 08 71 00, Door Hardware, page 08 71 00-3 line 49, add: "Electric Strike, Von Duprin 6200 series or equal."

CHANGES TO DRAWINGS:

2. 1D100 South Elevation Demolition
 - a. Revise note at lower roof to read: "Remove flashing and roof membrane over wood for reinstallation after removal of cedar planks. Existing rubber roof in this area is to remain and termination bar installed and sealed at face of existing CMU, see 1A100."
3. 6D100 Roof Plan Demolition
 - a. Add the following note: "The original 1967 drawings indicate a built-up roof with gravel over 1 1/2" rigid insulation over the 10" precast roof slab. Field Verify."
 - b. Add the following note at the existing metal canopy: "Remove existing flashing at existing metal canopy for installation of wall system, see 7A500."
4. 5A100 First Floor and Foundation Plan
 - a. At North Elevation Main Entrance HM Door and Frame revise note to read: "HM Door and Frame. Provide electric strike and rough in within HM frame for future connection to a power source and installation of a door release button. Coil 2 feet of wiring outside the head of the frame."
5. E201 First Floor Electrical Plan
 - b. Revise note 5 to read 'Remove existing fixture.'

- c. At East Elevation staff entry alcove revise key to note from note 6 to note 7.
- d. Under GENERAL NOTES, add "3. Fixture type OA to be Bega 33591-BLK (13 watt LED, 3000K color temperature, 120 volts).

Enclosures:

Pre- Bid Site Tour Sign-up Sheet

Henry Vilas Zoo Administration Building Reroofing and Recladding
Thursday, May 5, 2016 @ 1PM

HVZ RECLADDING & REROOFING
PRE-BID 05.05.16

NAME	REPRESENTING
Justin Hinkley	Nations Roof
Vince Laufenberg	Meltee Assoc.
Wade Porter	J.H. Findorff
Mike Schueck	Staff Electric
Michael Berndsen	Maly Roofing
CARMS ALLEN	ADVANCED BUILDING
Ricky C Hashelder	Hashelder Roofing
Mike Rineen	SunPeak
Dennis Bauer	Bauer-Baerlin Bldg
Theresa Tresner	Bauer & Raether Bldg.
Derek Westrum	Gary Brown Roofing
KURT FEMEL	DANIELS

1
KURT

