



DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive
Kathleen M. Falk

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director
Gerald J. Mandli

November 19, 2010

ATTENTION ALL REQUEST FOR PROPOSAL (RFP) HOLDERS

RFP NO. 310036 - ADDENDUM NO. 1

ENGINEERING SERVICES FOR TRUAX LANDFILL GAS EXTRACTION SYSTEM

PROPOSALS DUE: THURSDAY, DECEMBER 2, 2010, 2:00 PM. DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Proposal (RFP) and is hereby made a part of the RFP. Specifically, this Addendum addresses questions asked during the site tour. **Acknowledge this Addendum in your Proposal.**

PLEASE MAKE THE FOLLOWING CHANGES:

- 1. What is the required response time when the flare fails?**
As stated in Schedule A, Item 5.1, successful Proposer must respond to restart the flare, as specified under the attached exhibits, within twenty-four (24) hours of notice of flame failure
- 2. Will successful Proposer be responsible for testing condensate?**
As stated in Schedule A, Item 4, successful Proposer is not required to provide gas condensate sampling and analysis. Data derived from gas condensate analysis will be provided to successful Proposer by others for inclusion in reports prepared by successful Proposer as required under the foregoing exhibits
- 3. Will successful Proposer be responsible for testing groundwater and/or reporting results of groundwater and condensate testing performed by others?**
As stated in Schedule A, Item 2, successful Proposer is not required to monitor or analyze groundwater at the landfill site. Groundwater data will be provided to successful Proposer by others for inclusion in reports prepared by successful Proposer as required under the foregoing exhibits.
- 4. Is there an allowance for necessary repairs to the gas collection system?**
No, there is no allowance for repairs. If a repair will be less than \$50.00, successful Proposer shall make the repair without prior Owner approval and then invoice Owner for cost of repair. If a repair will be \$50.00 or more, successful Proposer must get Owner approval before making the repair. Owner will then pay for repairs that cost \$50.00 or more.

If any additional information about this Addendum is needed, please contact Mike Kirchner at 608/246-3393, Kirchner@msnairport.com.

Enclosures: N/A