



**DANE COUNTY DEPT. OF
PUBLIC WORKS, HIGHWAY &
TRANSPORTATION**

1919 Alliant Energy Center Way
Madison, Wisconsin 53713
Office: 608/266-4018 ♦ Fax: 608/267-1533
Public Works Engineering Division
Public Works Solid Waste Division

ADDENDUM

August 30, 2017

ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

RFB NO. 317027 - ADDENDUM NO. 1

VERONA COMMUNICATION TOWER & SHELTER DEMOLITION

BIDS DUE: TUESDAY, SEPTEMBER 5, 2017, 2:00 PM. DUE DATE AND
TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

PLEASE NOTE THE FOLLOWING CONTRACTOR SUBMITTED QUESTIONS:

Q1: What is the depth of the well on site?

A1: See attached Well Report.

Q2: What type of septic system is on site?

A2: There is no additional information available on septic system, but it is assumed to be a holding tank.

Q3: Is there lead paint on the tower or asbestos on the property?

A3: There is currently no knowledge of asbestos or lead paint on the property.

Q4: Is there any additional tower information?

A4: Tower is a Rohn model #80 guyed 445' tower constructed in 1970.

If any additional information about this Addendum is needed, please call Ryan Shore at 608/266-4475, shore@countyofdane.com.

Sincerely,
Ryan Shore
Project Manager

Enclosures:
Well Report

H:\Shared\ENGINEERING DIVISION\Ryan Shore\317027 - Verona Communication Tower Demolition\03 - Addendum\317027 - Addendum 1.docx

WELL CONSTRUCTOR'S REPORT

Well-6

JUL 1 1970

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Dane CHECK ONE Town Village City NAME Verona

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
SW, S.W. 1/4 Sec. 25, Twn 6N, Rng 8E.

3. OWNER AT TIME OF DRILLING
Dane County

4. OWNER'S COMPLETE MAIL ADDRESS
City County Building, Madison, Wisconsin

5. Distance in feet from well to nearest: (Record answer in appropriate block)	BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
	C.I.	C.I.	C.I.	SEWER CONNECTED	C.I.
	10	NONE			
				INDEPENDENT	TILE
CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN
C.I.	TILE				SILO
			NONE	NONE	ABANDONED WELL
					SINK HOLE

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for:
Radio Communications Building

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
14	Surface	7	6	40	265	Clay	Surface	12
10	7	40				Broken limestone	12	15
						Hard lime	15	58
7	Black 23.77 lbs per ft.	Surface		7		Crevice in lime	58	60
6 x7	moniter pitless adapter	7		8		Limestone	60	148
6	T & C sced. 40			8	40	Sandstone	148	265
	black 19.45 lbs. per ft.							
4	sced. 40 liner grouted	8		78		Samples to State Geologist office		

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
backfill	Surface	7
cement grout	7	40

11. MISCELLANEOUS DATA			
Yield test:	26	Hrs. at	12 GPM
Depth from surface to normal water level	120	ft.	
Depth to water level when pumping	126	ft.	

Well construction completed on June 23 19 70
Well is terminated 18 inches above below final grade
Well disinfected upon completion Yes No
Well sealed watertight upon completion Yes No

Water sample sent to State Laboratory of Hygiene laboratory on: June 23 19 70

SIGNATURE Peter H. Burno #607 Registered Well Driller COMPLETE MAIL ADDRESS DeForest, Wisconsin 53532

Please do not write in space below

COLIFORM TEST RESULT 5012	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS 672040 Plat
------------------------------	---------------	---------------	-----------	---------------------------