



DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive
Kathleen M. Falk

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director
Gerald J. Mandli

JULY 24, 2008

ATTENTION ALL REQUEST FOR PROPOSAL (RFP) HOLDERS

RFP NO. 108088 - ADDENDUM NO. 1

PUBLIC SAFETY COMMUNICATIONS CENTER INFRASTRUCTURE UPGRADES DESIGN PHASE

PROPOSALS DUE: THURSDAY, JULY 31, 2008, 2:00 PM. DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Proposal (RFP) and is hereby made a part of the RFP. Please attach this Addendum to the RFP.

PLEASE MAKE THE FOLLOWING CHANGES:

1. Agreement for Professional Services

Page A-7 - Article 3 (5):

Change: “ construction contingency ”, to: “ bidding contingency ”.

Page A-8 - Article 3 (7):

Change: “ construction contingency ”, to: “ bidding contingency ”.

Page A-8 - Article 3 (7) (b):

Change: “ construction contingency ”, to: “ bidding contingency ”.

ADDITIONAL GENERAL INFORMATION:

1. The associated emergency power generator set is a Onan model 200.00FP-17R/28920M, 200 kW / 250 kVA; circa 1988. It is located in the sub-basement, three floors below the Public Safety Communications Center.
2. Energy & power use are not monitored separately for the Public Safety Communications Center.
3. It is *expected* that carpeting will be replaced throughout the entire 911 Center.

4. It is *expected* that power & signal wiring will be tested, labeled, organized, & removed if not in use, in all spaces that have raised floors and/or equipment (radio, computer, electrical) rooms.
5. The County may require the design to be under NEC 2008, Article 708 which includes new requirements for Critical Operations Power Systems (COPS). This shall be determined with the State, County & consulting engineer.

If any additional information about this Addendum is needed, please call Scott Carlson at 608/266-4179, carlson.scott@co.dane.wi.us.

Sincerely,
Scott Carlson
Project Engineer

Enclosures:
N/A

S:\PubWork\Shared\Engineering Division\Scott Carlson\108088 - PSC 911 Consoles\108088 - PSC 911 Infrastructure\108088-Addendum1.doc