



**DANE COUNTY DEPT. OF  
PUBLIC WORKS, HIGHWAY &  
TRANSPORTATION**

1919 Alliant Energy Center Way  
Madison, Wisconsin 53713  
Office: 608/266-4018 ◊ Fax: 608/267-1533  
Public Works Engineering Division  
Public Works Solid Waste Division

# ADDENDUM

FEBRUARY 12, 2019

**ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS**

**RFB NO. 318045 - ADDENDUM NO. 1**

**JOB CENTER RESTROOM EXPANSION**

---

**BIDS DUE: TUESDAY, FEBRUARY 19, 2:00 PM. DUE DATE AND  
TIME ARE NOT CHANGED BY THIS ADDENDUM.**

---

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

**PLEASE MAKE THE FOLLOWING CHANGES:**

**CHANGES TO SPECIFICATIONS:**

- 1. Section 22 05 00 – Common Work Results for Plumbing**
  - a. Page 22 05 00-3, Line 22, add “Plumbing Fixtures and Trim”.
- 2. Section 22 42 00 – Commercial Plumbing Fixtures**
  - a. Page 220500 – 1, Line 52, Delete Line in its entirety.
  - b. Page 224200-2, Line 48, after the word “Elkay”, add “Model LKD-35”.
- 3. Section 23 09 93 – Sequence of Operation for HVAC Controls**
  - a. Page 2, Lines 26,27,28, Delete “Radiant Ceiling Panels and Convecor Radiation” (new and existing) and substitute the following:
    - a. The Radiant Ceiling Panel control shall be integrated into the existing building Direct Digital Control automation system.
    - b. Provide stainless steel flat plate sensor for each space with radiant ceiling panels at locations indicated on the drawings.
    - c. Add the radiant ceiling panels on the existing automation system floor plans and graphics.
    - d. The automation system shall indicate the temperature set point, space temperature and valve position.
    - e. Provide a low temperature alarm if the space temperature falls 10 degrees F (adjustable) below the set point. The alarm shall be capable of being disabled.
    - f. The space temperature set point shall be adjustable through the automation system.
    - g. Provide a new control valve for each radiant panel circuit.

**CHANGES TO DRAWINGS:**

**1. Drawing M2.0, Detail E, Hot Water Radiant Ceiling Panel Control.**

- a. Delete Sequence of Operation and substitute the following:
  - a. Refer to revised Sequence of Operation, Section 23 09 93, page 2 Radiant Ceiling Panel control as modified in this Addendum. The radiant ceiling panel control shall be integrated into the existing building direct digital control system.
  - b. The sequence shall apply to existing panels being relocated and new panels.
  - c. Sensors shall be stainless steel flat plate similar to existing. Existing may be reused if compatible with the new specified sequence.
  - d. Remove existing radiant ceiling panel control devices and wiring not required for the new automation system installation.

If any additional information about this Addendum is needed, please call Eric Urtes at 608/266-4798, [urtes.eric@countyofdane.com](mailto:urtes.eric@countyofdane.com).

Sincerely,  
*J. ERIC URTEES, AIA*  
Project Manager

Enclosures:  
Pre-Bid Site Tour Sign-Up Sheet

H:\Shared\ENGINEERING DIVISION\Eric Urtes \318045 - Job Center Restroom Expansion -- Addendum 1.docx

Dane County Job Center  
Job Center Restroom Expansion February 6, 2019 @ 1:30 PM

Name	Phone No. + e-mail Address	Company.
KURT FEMRITE	kfemrite@danielsco.com 608.576-7725	DANIELS
Cody Smith	CSmith@Funderoff.com (608) 381-7758	J. H. Funderoff
Isaac Lindert	ilindert@abcmadison.com (608) 833-0900	Advanced building corp
Jerry Gitlewski	920-360-0326 JERRY.GITLEWSKI@CBRE.COM	CBRE
DOU HAMMER	SAFETY PLUMBING DESIGN dcham1@TDS.NET	
GLENN KOHLER	222-8869	BCCI
George Jolwale	gjolwale - eng 370.com 608-225-9273	Eng 370
MARK GOLDEN	FORWARD CONSTRUCTION GROUP. 608.365-1984 mark@fcgbuilds.com	
Mike Collins		FM
SHAWN O'ROURKE		H/A/ve.
ERIC LUTES		PUBLIC WORKS

ALSO: SHAWN TESSMANN, LIZA INGRILLI, AND TONY SIS FROM HUMAN SERVICES WERE ALSO PRESENT.

