



**DANE COUNTY DEPT. OF  
PUBLIC WORKS, HIGHWAY &  
TRANSPORTATION**

1919 Alliant Energy Center Way  
Madison, Wisconsin 53713  
Office: 608/266-4018 ♦ Fax: 608/267-1533  
Public Works Engineering Division  
Public Works Solid Waste Division

# ADDENDUM

November 21, 2018

**ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS**

**RFB NO. 318016 - ADDENDUM NO. 2**

**MULTIPLE HIGHWAY GARAGE CNG RETROFIT**

---

**BIDS DUE:** TUESDAY, DECEMBER 4, 2018, 2:00 PM. DUE DATE AND TIME ARE CHANGED BY THIS ADDENDUM.

---

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

**PLEASE MAKE THE FOLLOWING CHANGES:**

**Drawings**

- 1. Section 23 05 23 - Valves and Piping for Fuel Gas**  
Page 2, Line 13
  - **Delete** “NEMA Type 4,4X” and **insert** “NEMA Type 1”
- 2. Sheet H100-Y - York Ventilation New Work Floor Plan**  
Fan Schedule
  - **Change** EF-3A,B,C, D, E to 1,800 CFM, 0.42 Ext Static Pressure
  - All other scheduled values remain the same.

If any additional information about this Addendum is needed, please call Eric Urtes at 608/266-4798, [urtes.eric@countyofdane.com](mailto:urtes.eric@countyofdane.com).

Sincerely,  
*Eric Urtes, AIA*  
Project Manager

Enclosures:  
N/A

H:\Shared\ENGINEERING DIVISION\Eric Urtes\318016 - Springfield and York Highway Garages - CNG Retrofit\03 - Addendum\318016 - Addendum 1.docx