



**DANE COUNTY
DEPARTMENT OF WASTE &
RENEWABLES**

1919 Alliant Energy Center Way
Madison, Wisconsin 53713
Office: 608/266-4018 ♦ Fax: 608/267-1533

ADDENDUM

NOVEMBER 12, 2019

ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

RFB NO. 319027 - ADDENDUM NO. 4

PHASE 11 & 12 LINER CONSTRUCTION

DANE COUNTY LANDFILL SITE NO. 2 (RODEFELD)

BIDS DUE: TUESDAY, NOVEMBER 19, 2019, 2:00 PM
DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. **All bidders must acknowledge this Addendum on the Bid Form.**

PLEASE MAKE THE FOLLOWING CHANGES:

CONTRACTOR QUESTIONS

Question 1: The Bid Form, Section 01270 (Schedule of Values and Payment), and Drawings all state “textured” geomembrane to be used for Phase 11 & 12 Construction. However, Section 02070 (HDPE Geomembrane) states that smooth geomembrane shall be used on the base of the cell and textured shall be used on the slopes and horizontal expansion area. Will smooth HDPE geomembrane be used on the base of the cell?

Answer: No, all geomembrane used in Phase 11 & 12 shall be textured.

If any additional information about this Addendum is needed, please call Robert Regan at 608/516-3159, Regan@countyofdane.com.

Sincerely,

Robert Regan, P.E.

Project Manager