



**DANE COUNTY DEPT. OF
PUBLIC WORKS, HIGHWAY &
TRANSPORTATION**

1919 Alliant Energy Center Way
Madison, Wisconsin 53713
Office: 608/266-4018 ♦ Fax: 608/267-1533
Public Works Engineering Division

ADDENDUM

AUGUST 26, 2020

ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

RFB NO. 320021 - ADDENDUM NO. 2

COURTHOUSE HVAC CONTROLS REPLACEMENT

BIDS DUE: TUESDAY, SEPTEMBER 1, 2020, 2:00 PM. DUE DATE AND
TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

PLEASE NOTE THE FOLLOWING CONTRACTOR SUBMITTED QUESTIONS:

Q1: Can you clarify that the Controls Contractor is responsible for providing the graphical interface on the existing Dane County Supervisor?

A1: Yes, the Controls Contractor needs to provide the graphics.

Q2: Can you clarify that there is not a Division 25 Systems Integrator that would be providing graphics on this job?

A2: Yes, there is no Division 25

Q3: Is there an AHU 3 involved in this job?

A3: There is no AHU 3.

If any additional information about this Addendum is needed, please call Todd Draper at 608/267-0119, draper@countyofdane.com.

Sincerely,
Todd Draper
Project Manager

Enclosures:
N/A

H:\Shared\ENGINEERING DIVISION\Todd Draper\320021 - Courthouse HVAC Controls\03 - Addendum\Addendum#3\320021-Addendum3.docx