



DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive
Kathleen M. Falk

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director
Gerald J. Mandli

December 10, 2008

ATTENTION ALL REQUEST FOR PROPOSAL (RFP) HOLDERS

RFP NO. 108147 - ADDENDUM NO. 1

LANDFILL GAS COMPRESSOR SYSTEM

PROPOSALS DUE: THURSDAY, DECEMBER 18, 2008, 2:00 PM CST. DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Proposal (RFP) and is hereby made a part of the RFP. **Please attach this Addendum to the RFP to acknowledge receipt of Addendum.**

PLEASE MAKE THE FOLLOWING CHANGES:

1. Landfill Gas Compressor System Specifications

Page 1 - Item 1.01.A.:

Change: "between 800 and 2000 scfm.", to: "between 600 and 2000 scfm."

Page 5 - Item 1.05.B.1.a.: Delete current line and replace with the following:

"Design operating suction pressure range: -6 hg vacuum is the lowest possible suction pressure, and the highest that suction pressure could be is 0 psig."

2. General Information

The Variable Speed Drive (VFD) is to be included in the FGC package scope.

The back pressure sensor and control logic signal to VFD is to be included in the FGC package scope.

The compound amounts listed in Air Toxics, Ltd 11/11/2008 report by Modified ASTM D-1945 are in Volume %.

If any additional information about this Addendum is needed, please contact Mike DiMaggio at 608/266-4990 or dimaggio.mike@co.dane.wi.us.