



# DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive  
Joseph T. Parisi

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713  
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director  
Gerald J. Mandli

October 2, 2014

## ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

### RFB NO. 314021 - ADDENDUM NO. 1

#### INSULATION FOR BLUE SHED HIGHWAY STORAGE FACILITY

---

**BIDS DUE:** TUESDAY, OCTOBER 7, 2014 AT 2:00 PM. DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.

---

This Addendum is issued to modify, explain or clarify the original Request for Bid, Proposal (RFB) and is hereby made a part of the RFB. Please Acknowledge this Addendum on the Bid Form.

#### PLEASE MAKE THE FOLLOWING CHANGES:

**1. Substitution Requests**

- a. DEMILEC<sup>®</sup>'s, HEATLOK SOY<sup>™</sup> 200 Plus closed-cell spray polyurethane foam insulation system is approved.
- b. A request to use 1/2 lb/cu ft polyurethane material is denied.

**2. No Asbestos**

The existing deteriorated insulation has been tested, and it does not contain asbestos.

**3. Electric Service**

The electrical service to this building has a minimum of 240V, 3-phase, 100 amp and 208V, 1-phase, 40 amp available at the electrical service panels. There may be more amperage than this available. If a contractor requires a larger service, please contact John Welch to verify availability.

**4. Paint Shop Area of Building**

The metal roof and wall panels in the paint shop area that is located on the north side of the CMU wall can be insulated entirely at one time. There is no need to split the paint shop area in half and provide partitions.

**5. CMU Wall**

There will not be any insulation applied to either side of the CMU wall that separates the paint shop area from the rest of the building.

**6. Abandoned Ducts**

There are a total of six (6) 12" round ducts that penetrate the roof of the building. These ducts are abandoned. Contractor shall remove the ducts and patch the roof holes with a sheet of compatible metal prior to insulating the roof.

**7. Heat Available**

The building has radiant heaters. These radiant heaters can be used to keep the building and roof and wall panels warm enough for insulation application, and Owner will pay for associate utility costs. Owner will not provide electrify for any additional heating needed beyond the heat provided by the radiant heaters.

**8. Restroom**

There is a restroom available for the Contractor to use in the main office building on the site.

**9. Blueprints Are Available**

The original building blueprints are available for viewing in the Dane County Public Works office located at 1919 Alliant Energy Center Way, Madison WI 53713.

If any additional information about this Addendum is needed, please contact John Welch at 608/516-4154, [welch@countyofdane.com](mailto:welch@countyofdane.com).