



**DANE COUNTY DEPT. OF
PUBLIC WORKS, HIGHWAY &
TRANSPORTATION**

1919 Alliant Energy Center Way
Madison, Wisconsin 53713
Office: 608/266-4018 ♦ Fax: 608/267-1533
Public Works Engineering Division

ADDENDUM

November 19, 2019

ATTENTION ALL REQUEST FOR BID HOLDERS

RFB NO. 319037 - ADDENDUM NO. 1

BUILDING AUTOMATION CONTROLS

BIDS DUE Tuesday, Dec 3, 2019, 2:00 PM. DUE DATE AND
TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Bid, RFB and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

PLEASE NOTE THE FOLLOWING CONTRACTOR SUBMITTED QUESTIONS:

- Q1: In one spot it says there are 66 VAV controllers. In another spot it says 56. What is the quantity?**
A1: Even though the numbering goes to 66, there are actually 56 VAV controllers on the second floor JACE 2 portion of this job.
- Q2: Do we have to hire a blancer to balance the VAV boxes so that the CFM readings are verified or will Dane County hire a balancer after the install is complete?**
A2: It will be the responsibility of the controls contractor to provide TAB services according to specification 23 05 93 which is part of the bid package.

If any additional information about this Addendum is needed, please call Todd Draper at 608/267-0119, draper@countyofdane.com.

Sincerely,
Todd Draper
Project Manager

Enclosures:
N/A

S:\PubWork\Shared\ENGINEERING DIVISION\Scott Carlson\316004 - Army Reserve Bldg Demo\03 - Addendum\316004-Addendum template.docx