



**DANE COUNTY DEPT. OF  
PUBLIC WORKS, HIGHWAY &  
TRANSPORTATION**

1919 Alliant Energy Center Way  
Madison, Wisconsin 53713  
Office: 608/266-4018 ♦ Fax: 608/267-1533  
Public Works Engineering Division

# **ADDENDUM**

---

AUGUST 24, 2020

**ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS**

**RFB NO. 320021 - ADDENDUM NO. 2**

**COURTHOUSE HVAC CONTROLS REPLACEMENT**

---

**BIDS DUE:** TUESDAY, SEPTEMBER 1, 2020, 2:00 PM. DUE DATE AND  
TIME ARE NOT CHANGED BY THIS ADDENDUM.

---

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

**PLEASE NOTE THE FOLLOWING CONTRACTOR SUBMITTED QUESTIONS:**

**Q1:** Do you want new control transformers for the power feeding the DDC Controllers?

**A1:** No the power supply to the panels and low voltage shall remain in existing configuration.

**Q2:** What should be done with the NAE enclosures?

**A2:** Remove the existing NAE enclosures and install new control panel for Jace.

**Q3:** Can the conductor for the thermostats be field checked to determine what is currently in place?

**A3:** Conductor has been field verified to be CAT 5E.

If any additional information about this Addendum is needed, please call Todd Draper at 608/267-0119, [draper@countyofdane.com](mailto:draper@countyofdane.com).

Sincerely,  
*Todd Draper*  
Project Manager

Enclosures:  
N/A

H:\Shared\ENGINEERING DIVISION\Todd Draper\320021 - Courthouse HVAC Controls\03 - Addendum\Addendum #2\320021-Addendum 2.docx