

JUNE 4, 2020

ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

RFB NO. 320013 - ADDENDUM NO. 1

FEN OAK GREENHOUSE

BIDS DUE: JUNE 9, 2020, 2:00 PM. DUE DATE AND
TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

PLEASE NOTE THE FOLLOWING CONTRACTOR SUBMITTED QUESTIONS:

Q1: Is an electrical sub-panel needed?

A1: Yes, contractor to provide a Square D QO 125 Amp 12-Space Outdoor Main Lug Load Center with Ground Bar and Main Breaker. Installation location to be field determined. All wiring must be copper.

Q2: Is the contractor responsible for water supply installation and hose bibs?

A2: Water supply and hose bib installation is owner's responsibility and should not be included in bid price.

Q3: Is the trench drain to be installed by the contractor?

A3: The trench drain has been eliminated and should not be included in the bid price.

Q4: What size of gas supply line should be provided?

A4: The gas supply line should be ¾".

If any additional information about this Addendum is needed, please call Ryan Shore at 608/445-0109, shore@countyofdane.com.

Sincerely,
Ryan Shore
Project Manager