



**DANE COUNTY DEPT. OF
PUBLIC WORKS, HIGHWAY &
TRANSPORTATION**

1919 Alliant Energy Center Way
Madison, Wisconsin 53713
Office: 608/266-4018 ◊ Fax: 608/267-1533
Public Works Engineering Division
Public Works Solid Waste Division

ADDENDUM

April 25, 2017

ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

RFB NO. 317015 - ADDENDUM NO. 1

LIBRARY SERVICE RENOVATION

**BIDS DUE: TUESDAY, MAY 2, 2017, 2:00 PM. DUE DATE AND
TIME ARE NOT CHANGED BY THIS ADDENDUM.**

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

PLEASE MAKE THE FOLLOWING CHANGES:

1. Section 10 28 00 Toilet and Bath Accessories
 - a. Page 2, C. Warm air dryers (DRYER) add. 1.b. Or approved equal by Saniflow Machflow.
2. Section 22 11 00 - Facility Water Distribution
 - a. Page 221100-3, line 20, add the following; "Schedule 40 Chlorinated Polyvinyl Chloride (CPVC) pipe and fittings, ASTM D-2826, F-441, F-442, F-437, F-438, and F439".
3. Section 22 42 00 - Commercial Plumbing Fixtures
 - a. Page 224200-1, line 48, add the following; "Water Closet WC-1: Floor set, tank type, white vitreous china siphon jet water closet with elongated bowl, 2-1/2" passageway, 1.28 gallon flush, white open front seat, less cover, tank locks, and insuliner.
Fixture: Kohler "Highline" K3999-UT-R2.
Supply/Stops: McGuire BV2165, BV2165CC, or BV175 as required with braided stainless steel closet riser.
Seat: Bemis Model 1055SS self-sustaining check hinge".
4. Section 26 31 11
 - a. In 2.02D, add "Equivalent clamps by Solar Connections International are acceptable."
5. Drawing C200 Site Plan
 - a. Revise length of fence to 48'-3" with posts at 6'-0" o.c. typical.
6. Drawing PD100
 - a. Delete the note "Existing water closet to remain (each room)"

7. Drawing P100
 - b. On the plan view and the Restroom Water Diagram, delete the words "Existing Water Closets".
 - c. Add the symbol "WC-1" at each water closet location on the floor plan and restroom water diagram.

8. Drawing M102 – Ductless Split Air Conditioner Schedule
 - d. At AC-1 Make the following revisions: Model, PKA-A36KA6; Nominal BTU Capacity, 34,200; Note 3, Sensible Heat Factor 0.70, Sensible Cooling 23,940 BTU.

If any additional information about this Addendum is needed, please call Eric Urtes, AIA – Project Manager 608.266-4798 or urtes.eric@countyofdane.com

Sincerely,
Eric Urtes, AIA
Project Manager

Enclosures:
Pre-bid tour attendees list

Library Service Renovation

RFB# 317015
04/20/17

Name	Company	Phone No. + Email
Dary Schulz	VAN ERT Electric	920-427-7149
John Wechiger	SGTS, INC	608-279-3057
Ron Schlafers	Van Ert Electric	608 440-0474
Ken Lusian	Ideal Builders	608-729-2361
Troy Harrison Aaron Rumberg	H/I Electric	608-256-2983
Nathan Parrette	Dave Jones	608-709-1462
Travis Wellington	Hooper Corporation	608-209-7421 twellington@ hoopercorp.com
Vince Laufenberg	McKee Associates	608-271-4900 vince@mckeeassoc.com ac.com

Library Service Renovation

RFB# 317015
04/20/17

Name	Company	Phone No. + Email
Jacob Cates	Joe Daniels const.	608-271-4300 OFFICE 608-235-1859 cell jcates@danielsco.com