

# ADDENDUM

November 6, 2018

## ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

### RFB NO. 318016 - ADDENDUM NO. 1

#### MULTIPLE HIGHWAY GARAGE CNG RETROFIT

---

**BIDS DUE:** TUESDAY, NOVEMBER 27, 2018, 2:00 PM. DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.

---

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

#### PLEASE MAKE THE FOLLOWING CHANGES:

##### Drawings

##### 1. Sheet H100-S

Modify current Sheet H100-S to include the following:

- At new exhaust fans EF-7A, 7B, 7C and & 7D the 30X18 ducts shall be run with the top tight to the structural beams.
- At new exhaust fans EF-7A, 7B, 7C and & 7D the 30X18 ducts shall be offset north to miss the lighting fixtures that are located at the center of the structural span.
- At new exhaust fans EF-7A, 7B, 7C and & 7D the 30X30 opening in top of duct shall have a 30X30 duct extended up to 12 inches below the ceiling.
- At EF-7A and 7D the duct extending to the end bays, with overhead doors, shall extend just a far as necessary to rise the 30x30 duct up.

##### 2. Sheet H100-S

Modify current Sheet H100-S HVAC New Work Keyed Notes as follows:

- Note 17: Change: 4 inch LP gas solenoid valve to “3 inch LP gas solenoid valve”.
- Note 17: Add: Connected load is 3,200 MBH.

##### 3. Sheet H100-Y

Modify current sheet H100-Y as follows:

- Detail BH100-Y: Add: 15”X15” elbow up and extend 15”X 15” duct up to terminate with open end duct 12 inches below ceiling.

##### 4. Sheet H100-Y

Modify current sheet H100-Y HVAC New Work Keyed Notes as follows:

- Note 24: Add: Connected load is 300 MBH.

If any additional information about this Addendum is needed, please call Eric Urtes at 608/266-4798, [urtes.eric@countyofdane.com](mailto:urtes.eric@countyofdane.com).

Sincerely,  
*Eric Urtes, AIA*  
Project Manager

Enclosures:  
N/A