



DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive
Joseph T. Parisi

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director
Gerald J. Mandli

RFB# 312012 ADDENDUM NO. 1

ISSUE DATE: June 18, 2012

CAMROCK PEDESTRIAN/BICYCLE BRIDGE #2 CAMBRIDGE, WISCONSIN 53523

BID DATE AND TIME IS UNCHANGED

This Addendum forms part of the Construction Documents and modifies the original Construction Documents dated June 7, 2012. Acknowledge receipt of this Addendum by inserting the number and issue date in the blank space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of two (2) pages total. Note drawings are to be printed in 30x42" sheets

CHANGES TO PROCUREMENT AND CONTRACTING REQUIREMENTS

Invitation to Bid (Legal Notice)

In the first paragraph: the dimensions are now 10'x100'

Bid Form, page BF - 1

Insert an Alternate Bid section included after this addendum to lay out Unit Pricing

Section 01000, pages 1 – 2

Section 1.2 'SUMMARY OF THE WORK' in Part A: the dimensions have changed to 10'x100'

Section 1.5 'ALTERNATES' omit Part C

CHANGES TO DRAWINGS:

Sheet 'Wetland Boardwalk Construction Details': The loading of the boardwalk is to be 10,000 pounds and should be designed for side mounted steel helical piles.

Alternate Bid - unit pricing

Dane County is inviting Bids to supply and install one (1) 10' x 100' wood boardwalk structure bridge for pedestrian and bicycle use in CamRock Park. The undersigned, having examined the site where the Work is to be executed and having become familiar with local conditions affecting the cost of the Work and having carefully examined the Drawings and Specifications, all other Construction Documents and Addenda thereto prepared by Dane County Department of Public Works, Highway & Transportation hereby agrees to provide all design expertise, labor, materials, equipment and services necessary for the complete and satisfactory execution of the entire Work, as specified in the Construction Documents, for the Alternate Bid unit pricing as follows:

Boardwalk Alternate:

- 100 ln.ft. – Boardwalk with steel helical piles as specified: @ \$ _____/ln.ft. =
- 100 ln.ft. – Boardwalk with alternate piling system: @ \$ _____/ln.ft. =

Total: \$ _____
Numeric Price

_____ and _____/100 Dollars
Written Price