



**DANE COUNTY DEPT. OF
ADMINISTRATION, PUBLIC
WORKS DIVISION**

1919 Alliant Energy Center Way
Madison, Wisconsin 53713
Office: 608/266-4018 ♦ Fax: 608/267-1533
Public Works Engineering Division

ADDENDUM

March 9, 2022

ATTENTION ALL REQUEST FOR BIDS (RFB, RFP) HOLDERS

RFB NO. 321045 - ADDENDUM NO. 4

FACILITIES EMERGENCY POWER

BIDS DUE: Tuesday , March 15, 2022, 2:00 PM. DUE DATE AND
TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Bid, (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

PLEASE MAKE THE FOLLOWING CHANGES:

PLEASE NOTE THE FOLLOWING CONTRACTOR SUBMITTED QUESTIONS:

Q1: Will the generators come with BACnet cards for integration?

A1: Yes.

Q2: Will the fuel tank monitoring system come with BACnet cards for integration?

A2: Yes.

Q3: Would the County provide network to the control panel?

A3: All wiring and infrastructure to be provided by EC/CC. County will enable communication.

Q4: Would this system be pulled back to the N4 server with Envysion or do you want it pulled back to the existing AX server?

A4: Any controls package that is bid should be N4 compatible and pulled back to the N4 server that is already in place with County Information Management.

Q5: The two generators that will be added are both in the basement. Can it be confirmed that this is the only place there will be controls work.

A5: The generators and fuel monitoring are the only devices in need of integration. Server and associated controls infrastructure are located elsewhere throughout the building.

Q6: Who is covering dampers/ actuators?

A6: The mechanical contractor is covering dampers. Controls contractor should cover actuators.

Q7: Do you want controls price to go to mechanicals, GC or directly to the County?

A7: Numbers for controls scope should go to the Mechanical Contractor.

If any additional information about this Addendum is needed, please contact Todd Draper at 608/267-0119, draper@countyofdane.com.

Sincerely,

Todd Draper

Project Manager

Enclosures:

N/A