



**DANE COUNTY DEPT. OF
PUBLIC WORKS, HIGHWAY &
TRANSPORTATION**

1919 Alliant Energy Center Way
Madison, Wisconsin 53713
Office: 608/266-4018 ♦ Fax: 608/267-1533
Public Works Engineering Division

ADDENDUM

July 16, 2021

ATTENTION ALL REQUEST FOR BID, PROPOSAL RFB HOLDERS

RFB NO. 320042 - ADDENDUM NO. 2

FACILITY REMODEL – EMERGENCY MANAGEMENT BUILDING

BIDS DUE: Tuesday, July 20, 2021, 2:00 PM. DUE DATE AND
TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Bid,RFB and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

PLEASE NOTE THE FOLLOWING CONTRACTOR SUBMITTED QUESTIONS:

- Q1:** The Architectural plans say 20 gauge, but the Structural says 14 gauge. Which is correct?
A1: In lieu of the 20 gauge metal studs notes on sheet A6.2 provide metal studs per the cold-formed steel wall schedule on sheet S-2.0
- Q2:** Is the waterproofing supposed to go all the way to the footing?
A2: Install per the detail 1/A3.3 and per manufacturers recommendations as noted.

If any additional information about this Addendum is needed, please contact Scott Carlson at 608/266-4179, Carlson.scott@countyofdane.com.

Sincerely,

Scott Carlson

Project Manager