



**DANE COUNTY DEPT. OF
PUBLIC WORKS, HIGHWAY &
TRANSPORTATION**

1919 Alliant Energy Center Way
Madison, Wisconsin 53713
Office: 608/266-4018 ♦ Fax: 608/267-1533
Public Works Engineering Division
Public Works Solid Waste Division

ADDENDUM

APRIL 27, 2017

ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

RFB NO. 317006 - ADDENDUM NO. 2

JAIL MITIGATION UPGRADES

BIDS DUE: TUESDAY, MAY 2 2017, 2:00 PM. DUE DATE AND
TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB.

PLEASE MAKE THE FOLLOWING CHANGES:

1. Section 00 01 10

Page 1: Delete:

“01 35 13.16 - Special Project Procedures for Detention Facilities
01 35 53 - Security Procedures”

2. Section 00 41 13

Page 1, Above “**BASE BID - LUMP SUM:**” Replace the black box with the following:

**NOTE: WISCONSIN STATUTE 77.54 (9M) ALLOWS FOR NO SALES & USE TAX ON
THE PURCHASE OF MATERIALS FOR COUNTY PUBLIC WORKS PROJECTS.**

3. Section 02 41 23

Page 1, line 11: After this line, insert the following:

“Applicable provisions of Divisions 00 & 01 govern work under this Section.”

4. Section 05 59 63

Page 1, line 14: Delete this line

Page 1, line 15:

Change: “Section 05 05 53: Security Metal Fastenings”, to: “Section 11 20 00: Security Fasteners”.

Page 1, line 18: After this line, insert the following:

“Applicable provisions of Divisions 00 & 01 govern work under this Section.”

5. Section 07 92 00

Page 1, line 16: After this line, insert the following:

“Applicable provisions of Divisions 00 & 01 govern work under this Section.”

6. Section 08 11 13

Page 1, line 13: After this line, insert the following:

“Applicable provisions of Divisions 00 & 01 govern work under this Section.”

7. Section 08 31 13.53

Page 1, line 12: Delete this line

Page 1, line 13:

Change: “Section 05 05 53: Security Metal Fastenings”, to: “Section 11 20 00: Security Fasteners”.

Page 1, line 15: After this line, insert the following:

“Applicable provisions of Divisions 00 & 01 govern work under this Section.”

8. Section 08 56 63

Page 1, line 12: Delete this line

Page 1, line 13:

Change: “Section 05 05 53: Security Metal Fastenings”, to: “Section 11 20 00: Security Fasteners”.

Page 1, line 15: After this line, insert the following:

“Applicable provisions of Divisions 00 & 01 govern work under this Section.”

9. Section 08 71 00

Page 1, line 16: After this line, insert the following:

“Applicable provisions of Divisions 00 & 01 govern work under this Section.”

Page 4, line 53:

Change: “ Section 05 05 53 ”, to: “ Section 11 20 00 ”.

10. Section 08 91 19

Page 1, line 15: After this line, insert the following:

“Applicable provisions of Divisions 00 & 01 govern work under this Section.”

11. Section 08 21 13

Page 1, line 13: After this line, insert the following:

“Applicable provisions of Divisions 00 & 01 govern work under this Section.”

12. Section 09 90 00

Page 1, line 11: After this line, insert the following:

“Applicable provisions of Divisions 00 & 01 govern work under this Section.”

13. Section 10 14 43

Page 1, line 9: After this line, insert the following:

“Applicable provisions of Divisions 00 & 01 govern work under this Section.”

14. Section 11 19 00

Page 1, line 1:

Change: “ EQUIPMENT ”, to: “ EQUIPMENT ”.

Page 1, line 22: After this line, insert the following:

“Applicable provisions of Divisions 00 & 01 govern work under this Section.”

Page 5, line 6:

Change: “ Section 11200 - Security Fasteners ”, to: “ Section 11 20 00 - Security Fasteners ”.

Page 6, line 45: After this line, insert the following:

“During demolition and installation of sliding devices within cellblocks, provide mechanical exhaust of all particulates created by the Work. Mechanical exhaust to be either direct venting through existing operable window or recirculating mechanical system. Where possible, air should be exhausted through a window to maintain a negative pressure in the work zone. Exhaust air filters are to be equal to MERV 18 (HEPA) or greater. Fan shall operate whenever dust or smoke generating work is being performed. Filters to be changed after work in each cellblock.”

Page 6, line 46:

Change: “ Section 07 70 00 contractor ”, to: “ Contractor ”.

15. Section 11 19 10

Page 1, lines 18-23: Delete these lines.

Page 1, line 28:

Change: “ Division 01 ”, to: “ Divisions 00 & 01 ”.

16. Section 11 19 20

Page 1, line 13: After this line, insert the following:

“Applicable provisions of Divisions 00 & 01 govern work under this Section.”

Page 6, line 54:

Change: “ Section 07 70 00 Contractor ”, to: “ Contractor ”.

17. Section 11 20 00

Page 1, line 24:

Change: “ Division 01 ”, to: “ Divisions 00 & 01 ”.

18. Section 23 05 00

Page 4, lines 10-11: Delete these lines & insert the following:

“Refer to Section 01 07 00 - Basic Requirements (Cutting and Patching) and Section 02 41 13 - Selective Demolition, Alteration, and Patching for general demolition requirements and procedures.”

19. Section 23 06 00

Page 2, line 14: After this line, insert the following:

“Refer to Drawing Sheet M001, Note 9 for duct cleaning Scope of Work.”

Page 4, line 19:

Change: “ A-003 ”, to: “ A004 ”.

20. Section 23 09 93

Page 1, lines 16-17: Delete these lines & insert the following:

“Section 23 34 23 - HVAC Power Ventilators”

21. Sheet A003

Modify current Sheet A003 as follows:

Change note: “ * TWO PARKING STALLS IN GARAGE FOR ... ”, to: “ * ONE PARKING STALL IN GARAGE FOR ... ”.

22. Sheet A101A

Modify current Sheet A101A, **KEYNOTE #5** by adding:

“Contractor responsible for re-working existing lock prep as required to accept new hardware as specified.”.

23. Sheet A601

Modify current Sheet A601, as follows:

Add to **NOTE #3**:

“Doors 6E8, 6E9, 6E29, 6E30, 6E31A, 6E31B: Contractor responsible for re-working existing lock prep as required to accept new hardware as specified.”

Add to **NOTE #4**:

“Door 6046: Contractor to replace existing hybrid Folger/Best mogul cylinder with new Folger Adam mogul cylinder as specified.”

Delete **NOTE #5** & replace with:

“Doors 6E54A and 6E60: Revise Door Schedule: Replace existing Adtec lock with new Folger Adam equivalent. Rework existing lock prep as required to accept new hardware.”

Add to **NOTE #10**:

“Doors S21 and S30: Contractor responsible for field measurement of new gates.”

Add to **NOTE #24**:

“Door 7E19-Southern Steel equivalents of Folger Adam series 110 locks acceptable. Equip locks with new Folger Adam mogul key cylinders.”

24. Sheet A602

Modify current Sheet A602, in **Notes** column of **DE DOOR SCHEDULE**, as follows:

Doors 7W1, 7034 and 7035: insert “ No Work ”

25. Sheet M001

Modify current Sheet M001, **GENERAL NOTE 9.C**, as follows:

Change: “ A003 ”, to: “ A004 ”.

If any additional information about this Addendum is needed, please call Scott Carlson at 608/266-4179, carlson.scott@countyofdane.com.

Sincerely,
Scott Carlson
Project Manager

Enclosures:
N/A