



DANE COUNTY DEPARTMENT of PUBLIC WORKS, HIGHWAY and TRANSPORTATION

County Executive
Joseph T. Parisi

1919 Alliant Energy Center Way ♦ Madison, Wisconsin 53713
Phone: (608) 266-4018 ♦ Fax: (608) 267-1533

Commissioner / Director
Gerald J. Mandli

February 02, 2015

ATTENTION ALL REQUEST FOR BID (RFB) HOLDERS

RFB NO. 315001 - ADDENDUM NO. 1

ALLIANT ENERGY CENTER SITE LIGHTING IMPROVEMENTS

BIDS DUE: Tuesday, February 10, 2015, 2:00 PM. DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.

This Addendum is issued to modify, explain or clarify the original Request for Bid (RFB) and is hereby made a part of the RFB. Please attach this Addendum to the RFB

PLEASE MAKE THE FOLLOWING CHANGES:

1. 1/26/2015 Walkthrough Attendance List

The the attendance list from the 1/26/2015 site tour is included with this addendum.

2. Section 26 56 00

Page: 3

Section Title: ACCEPTABLE MANUFACTURERS AND LUMINARIES

Change: “f. GLEON-AE-03-LED-480-5MQ-BZ for 120-277 volt walkway poles.”
to: “f. GLEON-AE-03-LED-480-5MQ-BZ for 480 volt walkway poles.”

Change: “Potential approved substitutes include” to: “The following series of alternate fixtures may be used provided luminary meets or exceeds all requirements laid out in section 26 56 00 (Including the technical criteria listed for the specified Gleon units used as basis of design) and the bid documents. Bidder is responsible for ensuring specifications and requirements are met.

1. Lithonia Lighting D Series LED
2. GE Lighting Evolve LED Area Light
3. RAB, inc. ALED 2T Series
4. Cree OSQ Series
5. Cree Edge Series”

Page: 7

Section Title: ALTERNATE BID 2

Change: "Replace wiring in existing lighting pole with UF wire and add inline 10 amp fuse to lighting pole at handhold."

to: "Replace wiring in existing lighting pole with single UF wire to feed both fixtures and add a new inline 10 amp fuse and a new fuseholder to lighting pole at handhold."

3. Bid Form

Page BF-2 ALTERNATE BID 2 - LUMP SUM: LIGHTING POLE WIRING AND FUSE:

Change: "Add price for replacing wiring and fuse in all existing lighting poles (including 108-117) as described in Specification Section 26 56 00"

to: "Add price for replacing wiring and installing new fuse and new fuseholder in all existing lighting poles (including 108-117, but not including 212-249) as described in Specification Section 26 56 00"

If any additional information about this Addendum is needed, please call Eric Urtes at 608-266-4798, Urtes.Eric@countyofdane.com.

Sincerely,

Eric Urtes

Project Manager

Enclosure:

WalkthroughAttendanceList.pdf

G:\My Documents\SWC Files\updated PW forms\1-JS approved-done & in use\Addendum 04-14-12.doc

Alliant Energy Center Site Lighting
 1919 Alliant Energy Center Way
 January 26, 2015 @10:00 AM

Name	Company/Email Address	Phone No.
Dan Evenson	Red Arrow Electric redarrowelectric@hotmail.com	608-516-3116
Kyle Falvey	Grunau Company kyle.falvey@grunau.us	414-406-0583
Amy Rose-Offord	Grainger amy.rose-offord@grainger.com	608-577-0124
Jim Kopp	Precision Drive & Control, Inc jkopp@precisiondrive.com	608-328-5600 Ext 440
Mike Pohlman	Nickles Electric mpohlman@nickleselectric.com	608-222-3456
Mike Simonson	H&H Electric msimonson@hhelectric.com	608-268-5914
Aaron Ramberg	Hill Electric aramber@hillelectric.com	608-256-2982
Rob Horkan	Total Electric rhorkan@totalelectric.com	608-345-3349
Brett Stillwagon	Cree brett.stillwagon@cree.com	616-566-3202
Chris Chiamonte	MAC Solutions, Inc chris@lightaudit.com	708-334-4370
Bill Fuchs	Logical Green Solutions wfuchs@logicalgreensolutions.com	262-547-1111 Ext 205
Vinko Iyasele	Toki and Associates viyasele@tokiandassociates.com	414-463-2700