

NOVEMBER 29, 2022

**ATTENTION ALL REQUEST FOR PROPOSALS (RFP) HOLDERS**

**RFP NO. 322037 - ADDENDUM NO.2**

**DESIGN SERVICES FOR LAW ENFORCEMENT TRAINING CENTER EXPANSION**

---

**PROPOSALS DUE: TUESDAY, DECEMBER 6, 2022, 2:00 PM. DUE DATE AND TIME ARE NOT CHANGED BY THIS ADDENDUM.**

---

This Addendum is issued to modify, explain or clarify the original Request for Proposal (RFP) and is hereby made a part of the RFP. Please attach this Addendum to the RFP.

**PLEASE NOTE THE FOLLOWING CORRECTION REGARDING STORMWATER MANAGEMENT REQUIREMENTS:**

**FROM ADDENDUM 1:**

**Q5:** Will a stormwater management plan be required?

**A5:** Based on current information a stormwater management plan will not be required.

**CORRECTION:** The proposed development needs to meet redevelopment standards:

- Stable outlet
- 40% Sediment Control for new Access Drives
- Capture First 1/2" Runoff with Green Infrastructure
- Thermal Control (Not Applicable)
- Oil & Grease Control (Not Applicable)

If any additional information about this Addendum is needed, please contact Ryan Shore at 608/445-0109, shore@countyofdane.com.

Sincerely,

*Ryan L Shore*

Project Manager

Enclosures:  
NA